

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Location of Construction: 82 Rackleff St		Owner Name: Eldridge, Cathering	Owner Address: 82 Rackleff St	Permit No: 05-0736	Issue Date: JUN 24 2005	Phone: 207-889-5151	Zone: R-5
Business Name:		Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	CITY OF PORTLAND			
Lessee/Buyer's Name		Phone:	Permit Type: HVAC	CEO District: 3			
Past Use: Single family		Proposed Use: Single family install 275 gal oil tank	Permit Fee: \$39.00	Cost of Work: \$39.00	INSPECTION: Use Group: V Type: Heating		
Proposed Project Description: Install 275 gal oil tank			FIRE DEPT: <input type="checkbox"/> Approved <input type="checkbox"/> Denied Signature: [Signature]	INSPECTION: Signature: [Signature]			
			PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions Signature: _____ Date: _____				
Permit Taken By: dmartin		Date Applied For: 06/07/2005	Zoning Approval				

Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input checked="" type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: 6/22/05	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: 6/22/05
--	---	--

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 05-0736		Date Applied For: 06/07/2005	CBL: 122 D012001
Location of Construction: 82 Rackleff St	Owner Name: Eldridge, Cathering	Owner Address: 82 Rackleff St	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	Phone (207) 883-9515
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	
Proposed Use: Single family install 275 gal oil tank		Proposed Project Description: Install 275 gal oil tank	

Dept: Building**Status:** Approved with Conditions**Reviewer:** Tammy Munson**Approval Date:** 06/22/2005**Note:****Ok to Issue:**

- 1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules



FILL IN AND SIGN WITH INK

122 D C12

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

To the **INSPECTOR OF BUILDINGS, PORTLAND, ME.**

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the **Laws** of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 82 RACKLEFF ST. Use of Building _____ Date 5/26/15
Name and address of owner of appliance CAT ELDORIDGE
82 RACKLEFF ST.
Installer's name and address DEAD RIVER CO 73 PLEASANT HILL RD SCARBOROUGH, ME 04070
Telephone _____

Location of appliance:

- ☒ Basement ☐ Floor
☐ Attic ☐ Roof

Type of Fuel:

- ☐ Gas ☒ Oil ☐ Solid

Appliance Name: 275 OIL TANKU.L. Approved ☐ Yes ☐ NoWill appliance be installed in accordance with the manufacture's installation instructions? ☒ Yes ☐ No

IF NO Explain: _____

The Type of License of Installer:

- ☐ Master Plumber # _____
☐ Solid Fuel # _____
☐ Oil # MS 30008710
☐ Gas # _____
☐ Other _____

Type of Chimney:


- ☒ Masonry Lined
Factory built _____

- ☐ Metal
Factory Built U.L. Listing # _____

- ☐ Direct Vent
Type _____

Type of Fuel Tank

- ☒ Oil
☐ Gas

Size of Tank 275 GALLONNumber of Tanks 1Distance from Tank to Center of Flame 20' feet.Cost of Work: \$ 1,550.00Permit Fee: \$ 39.00**Approved****App with Conditions**

Fire: _____

☐ See attached letter or requirement

Ele.: _____

Bldg.: _____

Inspector's Signature _____

Date Approved _____


Signature of Installer David M. [Signature] - DEAD RIVER CO

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy



installation and maintenance guidelines for aboveground domestic fuel oil tanks (PDF)

OUTSIDE FINISH

- o Preparation: **Washed and phosphated**
- Electrostatic powder paint "black or gray".

GENERAL CHARACTERISTICS

- o Always a tough tank
- Welded lap joint: the strongest one
- Ergonomic handle on each head for easy handling

NEW PRODUCTS:

- 275 gals. UL 80 labelled 10 **gauge** shell &

IN REFERENCE TO: UL LISTING

UL Listing: Requires outlet opening of 1/2" minir to be located underneath the tank only. Requires openings to be 2" minimum diameter. Tanks **whic** not meet above requirements cannot be **UL 80 la**

NOTICE: N.F.P.A. Codes, **UL** and Granby Steel Tanks require t these tanks be *tested* at job site before being put in service. To te tank, apply internal air pressure of not less than 3 **PSIG** or more t **PSIG** and soap all seams and welded areas. Warning: Over pressurization m y cause tank to fail.





73 PLEASANT HILL ROAD, P.O. BOX 467 - SCARBOROUGH, MAINE 04070-0467

(207) 883-9515 1-800-287-9993 FAX (207) 883-5921

COPY

SALES PROPOSAL

PROPOSAL SUBMITTED TO:	ACCOUNT NUMBER	PROPOSED BY:
CAT ELDRIDGE	48852	Mark Solomon
STREET	PHONE NUMBER	JOB PHONE
82 RACKLEFF STREET	761-1658	
CITY, STATE, AND ZIP CODE	JOB LOCATION	
PORTLAND ME 04103	SAME	

WE HEREBY SUBMIT SPECIFICATIONS AND ESTIMATES FOR:

THE INSTALLATION OF A 275 GALLON OIL TANK PACKAGE TO REPLACE THE EXISTING OIL TANK.

INCLUDES:

- o Removal and disposal of existing oil tank.
- o Transfer of existing oil into new tank.
- o All 1 1/2 black iron pipe needed for fill and vent.
- o A new tank gauge and whistle.
- A new copper oil line sleeved in plastic with a new oil filter.
- Complete system start-up.

Signed
6/6

DEAD RIVER CO. WARRANTS THIS INSTALLATION FOR 1 YEAR, PARTS AND LABOR.

THIS PROPOSAL IS SUBJECT TO THE CREDIT MANAGER'S APPROVAL.

WE HEREBY PROPOSE TO FURNISH LABOR AND MATERIALS - COMPLETE IN ACCORDANCE WITH THE ABOVE SPECIFICATIONS FOR THE SUM OF: ONE THOUSAND FIVE HUNDRED FIFTY DOLLARS AND 00/100 (\$1,550.00)

PAYMENT TO BE MADE AS FOLLOWS:

CONTRACT PRICE: \$1,550.00
LESS DOWN PAYMENT: \$ 516.00
BALANCE DUE: \$1,034.00

AUTHORIZED SIGNATURE: Mark Solomon (gsl)

DATE: MAY 17, 2005

ALL MATERIAL IS GUARANTEED TO BE AS SPECIFIED. ALL WORK TO BE COMPLETED IN A WORKMANLIKE MANNER ACCORDING TO STANDARD PRACTICES. ANY ALTERATION FROM ABOVE SPECIFICATIONS INVOLVING EXTRA COSTS WILL BE EXECUTED ONLY UPON WRITTEN ORDERS, AND WILL BECOME AN EXTRA CHARGE OVER AND ABOVE THE ESTIMATE. ALL AGREEMENTS CONTINGENT UPON STRIKES, ACCIDENTS OR DELAYS BEYOND OUR CONTROL. OWNER TO CARRY FIRE, TORNADO AND OTHER NECESSARY INSURANCE. OUR WORKERS ARE FULLY COVERED BY WORKER'S COMPENSATION INSURANCE. DEAD RIVER COMPANY CAN NOT REMOVE ASBESTOS. IF ASBESTOS IS PRESENT A CERTIFIED ABATEMENT COMPANY WILL BE REQUIRED AT AN ADDITIONAL CHARGE.

ACCEPTANCE OF PROPOSAL

THE ABOVE PRICES, SPECIFICATIONS AND CONDITIONS (LISTED ON THE OTHER SIDE) ARE SATISFACTORY AND ARE HEREBY ACCEPTED. YOU ARE AUTHORIZED TO DO THE WORK SPECIFIED. PAYMENT WILL BE MADE AS OUTLINED ABOVE.

NOTES: THIS PROPOSAL MAY BE WITHDRAWN BY DEAD RIVER COMPANY IF NOT ACCEPTED WITHIN 30 DAYS.

SIGNATURE: _____


DATE OF ACCEPTANCE: _____

SIGNATURE: _____

Mon 6/6



Limited Partnership



*Always
a Tough To
Warranty 3*

UL 80 Domestic Oil Tanks

UL 80 Domestic Oil Tanks are designed for use in residential and commercial applications. They are constructed of steel and are available in a variety of sizes and configurations. They are designed to be used for the storage of oil and are tested to meet the requirements of the UL 80 standard.

#PRODUIT	MODELS	DIMENSIONS			GAUGE	WEIGHT
		H	W	L		
2090	120 us gals vertical	47"	2 J	30"	12 ga	165 lb
2095	120 us gals horizontal	23"	47"	30"	12 ga	165 lb
2080	138 us gals vertical	44"	27"	30"	12 ga	175 lb
2085	138 us gals horizontal	27"	44"	30"	12 ga	175 lb
2070	220 us gals vert /stubbies	44"	27"	48"	12 ga	240 lb
2075	220 us gals horizontal	27"	44"	48"	12 ga	240 lb
2020	240 us gals narrow/vert.	47"	23"	60"	12 ga	260 lb
2025	240 us gals narrow/horiz.	23"	47"	60"	12 ga	260 lb
2040	275 us gals vertical	44"	27"	60"	12 ga	280 lb
2045	275 us gals horizontal	27"	44"	60"	12 ga	280 lb
2050	330 us gals vertical	44"	27"	72"	12 ga	320 lb
2055	330 us gals horizontal	27"	44"	72"	12 ga	320 lb

20 20 20 20
12" 12" 12" 12"



TECHNICAL SPECIFICATIONS

- o Steel ASTM A-569
- o Female openings NPT
- o Tested at pressure 5 to 7 PSIG
- o UL 80 label
- Operation at atmospheric pressure only
- o Also available UL 142 labeled on 275 & 330 gals (including a 3" diameter emergency vent opening). Other models on request only.