DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

JMB PROPERTIES LLC /Joe Flynn

Located at

342 WOODFORD ST

PERMIT ID: 2013-01235

ISSUE DATE: 07/09/2013

CBL: 122 E012001

has permission to Interior renovations, frame 2 closets, instal new cabinets, replace fixtues in existing bathrooms, upgrade electric

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning single family dwelling was the last approved use

Building Inspections

Fire Department Classification:

One or Two Family Dwellings

ENTIRE

2009 NFPA

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing Electrical Close-in Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 06/14/2013 2013-01235 122 E012001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: claiming that this is a duplex without a change of use -see #2013-Interior renovations, frame 2 closets, instal new cabinets, replace 01235 for the change of use fixtues in existing bathrooms, upgrade electric **Dept:** Zoning **Status:** Approved w/Conditions Reviewer: Marge Schmuckal **Approval Date:** 06/24/2013

Ok to Issue:

Conditions:

Note:

- 1) This permit is being approved on the basis of revised plans submitted. Any deviations shall require a separate approval before starting that work.
- 2) This property shall remain a two family dwelling with the issuance of permit #2012-01299.. Any further change of use shall require a separate permit application for review and approval.

 Dept:
 Building
 Status:
 Approved w/Conditions
 Reviewer:
 Tammy Munson
 Approval Date:
 06/26/2013

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 2) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Chris Pirone
 Approval Date:
 07/03/2013

 Note:
 Ok to Issue:
 ✓

Conditions:

- A sprinkler system is recommended but not required based on the following:
 Plans indicate the addition will not exceed _50_% of the total completed structure.
- 2) Required only in areas affected by the renovation:
 - Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations:
 - (1) All sleeping rooms
 - (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms
 - (3) On each level of the dwelling unit, including basements.
 - Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations:
 - (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms
 - (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces
- 3) All construction shall comply with City Code Chapter 10.