

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Permit Number: 090895

Please Read Application And Notes, If Any, Attached

This is to certify that Pinkham, Anissa Jill & David Potter/Phyllis Chase

has permission to Remove existing wood foundation & replace with 10" concrete.

AT 37 Higgins St CBL 122 G001001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise closed-in. 24 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____

Health Dept. _____

Appeal Board _____

Other _____
Department Name

Thomas M. Markley 9/1/09
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

CLOSED S m H
9-17-09

9-15-09

Foundation wall at 4' water proof
Framed per permit
OK to backfill. SMH.

9-17 work complete
done