

Rice Realty  
First Floor  
658 Congress Street  
Portland, Maine 04101  
(207) 773-1814

October 4, 2010

Inspector Brad C. James  
City of Portland  
Fire Department  
380 Congress Street  
Portland, Maine 041010022

Re: 103 Highland Street  
Building No. 68535-0-0

Dear Inspector James,


We have received your inspection report dated September 2, 2010. All apartments presently have hardwired carbon monoxide alarms.

We will install one (1) hour fire doors with self-closing hinges, in the front hallway apartment doors by November 5, 2010.

Basement and back hallway apartment fire doors will be installed and completed by March 7, 2011.

Thank you.

Yours truly,



---

Geoffrey I. Rice