Form # P 01

ELECTRICAL PERMIT
City of Portland, Me.

133-K-008

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 06 December 1996

LOCATION: 117 Revere St

Permit # 14285

OWNER Shuper **ADDRESS**

								TOTAL	EACH FEE
OUTLETS									
	Receptacles		Switches		Smoke Detector			.20	
FIXTURES	(number of)								
	incandescent		fluorescent					.20	
	fluorescent strip							.20	
SERVICES									
	Overhead Upgrade - Fuses to Break				TTL AMPS TO	800	100	15.00	15.00
	Underground					800		15.00	
TEMPORARY SERV.									
	Overhead				AMPS OVER	800		25.00	
	Underground					800		25.00	
METERS	(number of)							1.00	
MOTORS	(number of)							2.00	
RESID/COM	Electric units							1.00	
HEATING	oil/gas units							5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens			2.00	
	Water heaters		Fans		Dryers			2.00	
Disposals	Dishwasher		Compactors		Others (denote)			2.00	
MISC. (number of)	Air Cond/win							3.00	
	Air Cond/cent							10.00	
	Signs							5.00	
	Pools							10.00	
	Alarms/res							5.00	
	Alarms/com							15.00	
	Heavy Duty							2.00	
	Outlets								
	Circus/Carnv							25.00	
	Alterations							5.00	
	Fire Repairs							15.00	
	E Lights							1.00	
	E Generators							20.00	
	Panels							4.00	
TRANSFORMER	0-25 Kva							5.00	
	25-200 Kva							8.00	
	Over 200 Kva							10.00	
					TOTAL AMOUNT DUE				
	MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**		**25.00**		25.00

INSPECTION: Will be ready 12/09 noon or will call

CONTRACTORS NAME Daniel Merchant

ADDRESS 33 Constitutional Dr ~~XXXXXXXXX~~ Westbrook

TELEPHONE ~~797-8014~~ ~~856-7053~~ 854-9293

MASTER LICENSE No. 14285

LIMITED LICENSE No.

SIGNATURE OF CONTRACTOR Daniel D. Merchant

INSPECTION: Service 12/9/96 by [illegible]

Service called in 12/9/96

Closing-in _____ by _____

PROGRESS INSPECTIONS: 12/4/96 (SERVICE

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

ELECTRICAL INSTALLATIONS—

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection 12/9/96

By Inspector [illegible]

DATE:	REMARKS:
12/9/96	Electrician used regular sheetrock screws on outside service & meter, and did not install grounding wire for ground rod in 1/2" PVC ("out of site out of mind") (Dan Merchant)