

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

KAHN BARRY & JEAN JTS & VICKI L SCHAFFER

Located at

61 PROSPECT ST

PERMIT ID: 2016-02856

ISSUE DATE: 01/27/2017

CBL: 124 F003001

has permission to **For the installation of 3 electronic Mitsubishi wall heat pump system and 1 outdoor system.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

Fire Official

/s/ Greg Gilbert

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group: **Type:**

Single Family Residence

ENTIRE

2009 IRC / MUBEC

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Electrical - Residential
Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02856	Date Applied For: 11/09/2016	CBL: 124 F003001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Two family residence		Proposed Project Description: For the installation of 3 electronic Mitsubishi wall heat pump systems and 1 outdoor system.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Jennifer Thompson	Approval Date: 11/30/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 01/27/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) R302.4 Dwelling unit rated penetrations. Penetrations of wall or floor/ceiling assemblies required to be fire-resistance rated in accordance with Section R302.2 or R302.3 shall be protected in accordance with this section.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) The installation must comply with UL, the Manufacturers' Listing, MUBEC (IRC, 2009), and State of Maine Gas Regulations.				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 12/05/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code.				
2) Shall meet the requirements of 2009 NFPA 1 Fire Code.				