CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/26/17

Floor 3

Stairs down to ground

Please show where the 2nd egress stair is from the dwelling