

Celeste Ba -
Requirement



Inspection Services
P. Samuel Hoffses
Chief

Planning and Urban Development
Joseph L. Gray Jr.
Director

JULY 01, 1996

CITY OF PORTLAND

GOODIE RICHARD B
63 REVERE ST
PORTLAND ME 04103

Re: 63 REVERE ST
OBL: 124- J-008
DU: 4

Dear Mr. Goodie:

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above-referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems:

- 1. INT - REAR STAIRS - 100.40
HANDRAILS ARE MISSING
- 2. INT - OVERALL - 113.50
HARD-WIRED BATTERY-BACKUP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Arthur Rowe
Code Enforcement Officer

Tammy Munson
Code Enfc. Offc./ Field Supv.