

470-472 DEERING AVENUE



Full cut #9201 - Half cut #9202R - Third cut #9203R - Fifth cut #9204



APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Dec. 2, 1982

01084

PERMIT ISSUED

DEC 3 1982

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 474 Deering Avenue Use of Building multi family -3 No. Stories 2 New Building Existing " x
Name and address of owner of appliance Elaine Harper - same
Installer's name and address Ballard Oil & Equip- 135 Marginal Way Telephone 772-1991

General Description of Work

To install Steam boiler & burner unit - replacement

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? # 2 fuel oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 4' all around
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue 12 x 12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Carlin - gun Labelled by underwriters' laboratories? ye
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 14
Location of oil storage basement Number and capacity of tanks 275 gal.
Low water shut off yes Make McDonald Miller No. 67
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 275 gal.

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 15.00

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

CS 300

FILE COPY

Signature of Installer

PERMIT TO INSTALL PLUMBING

Date Issued **4-11-73**
 Portland Plumbing Inspector
 By **ERNOLD R GOODWIN**

Address **470 Deering Ave.** PERMIT NUMBER **0235**
 Installation For **Multi**
 Owner of Bldg. **Guy Melcher, Jr.**
 Owner's Address **Same**
 Plumber **Northern Utilities** Date **4-11-73**
 NEW REPL **5 Temple St.** NO. FEE

App. First Insp.		App. Final Insp.		Type of Bldg.	
Date		Date		☐ Commercial	
By		By		☐ Residential	
				☐ Single	
				☐ Multi Family	
				☐ New Construction	
				☐ Remodeling	

Item	NO.	FEE
SINKS		
LAVAS		
TO		
PA		
SH		
ST. FACE		
TANKS		2.00
GARBAGE		
SEPTIC TANKS		
PUMPERS		
WATER		
AUTOMATIC WASHERS		
DISHWASHERS		
OTHER		
TOTAL		2.00

Building and Inspection Services Dept. Plumbing Inspection



RS RESIDENCE ZONE
CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION
COMPLAINT

Location

472 Deering Ave.

INSPECTION COPY

COMPLAINT NO. 72/73

Date Received July 25, 1972

Location 472 Deering Avenue Use of Building Apartment house
Owner's name and address Allan Harper, 403 Deering Ave. Telephone _____
Tenant's name and address _____ Telephone _____
Complainant's name and address neighbor Telephone _____

Description: Changed from 2 to 3 families without a permit.

NOTES:

10/13/72 - OK was taken care of
through an appeal:

[Large handwritten mark, possibly a stylized 'Z' or '7', with a diagonal line through it.]



APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, May 4, 1955

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ alter ~~existing~~ ~~demolish~~ ~~construct~~ the following building ~~structure~~ ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 470 Deering Ave. Within Fire Limits? no Dist. No. _____
 Owner's name and address Francis L. Thompson, 470 Deering Ave. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address George F. Stanford, R1 E. D. #1, Scarborough Telephone _____
 Architect _____ Specifications _____ Plans yes No. of sheets 1
 Proposed use of building dwelling house No. families _____
 Last use _____ " " No. families _____
 Material wood No. stories 2 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____
 Estimated cost \$ 500. Fee \$ 2.00

General Description of New Work

To remove existing 1-story open piazza and to construct 1-story open piazza on right hand side of building 6' x 12' in jog of building.

4x8 plate - 6' span

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO George F. Stanford

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate 11' Height average grade to highest point of roof 11'
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation lally columns at least 4' below grade Thickness, top 3 1/2" bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof flat Rise per foot _____ Roof covering tar and gravel
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing lumber—Kind hemlock Dressed or full size? _____ dressed _____
 Corner posts 5x5 Sills 4x8 (Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor 2x8 _____, 2nd _____, 3rd _____, roof 2x8 _____
 On centers: 1st floor 16" _____, 2nd _____, 3rd _____, roof 16" _____
 Maximum span: 1st floor 8' _____, 2nd _____, 3rd _____, roof 8' _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

OK-5/4/55-ajp

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes


Francis L. Thompson

Signature of owner by: Richard P. Stanford

INSPECTION COPY

NOTES


5-12-55 Don. work about
done
5-19-55 Completed
Well done M.F.C.



Permit No. 551409
 Location 470 Leaning Lane
 Owner Francis J. Thompson
 Date of permit 5/4/55
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice

5-11
5-18

Francis L. Thompson
 170 Learning Ave



FILL IN COMPLETELY AND SIGN WITH INK

Permit No. 0977



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, July 1, 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 470 Deering Avenue Use of Building Residence
Name and address of owner Miss Luena F. Sands, 470 Deering Ave., City Ward 8
Contractor's name and address Easternoil Inc., 135 Marginal Way Telephone 3-6495

General Description of Work:

To install One Model A Easternoil Automatic Oil burner, 275 gal. tank.

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which floor? concrete Kind of Fuel oil
Material of supports of heater or equipment (concrete floor or what kind) concrete
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 2' 0"
from top of smoke pipe 2' 0", from front of heater 2' 0" from sides or back of heater 2' 0"

IF OIL BURNER

Name and type of burner Easternoil-gun type Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? no Type of oil feed (gravity or pressure) pressure
Location oil storage cellar No. and capacity of tanks one 275 gal.
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? one

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor

Easternoil Inc.
By Carl J. Bates 7/5/36

Ward 8 Permit No. 36/971

Location 470 Deering Ave

Owner Emma F. Sands

Date of permit 7/1/36

Notif. closing-in

Inspn. closing-in

Final Notif. 7/6/36

Final Inspn.

Cert. of Occupancy issued

NOTES

1. Kind of heat *Hot Water*
2. Label *✓*
3. Anti-siphon *✓*
4. Oil storage *✓*
5. Tank distance *✓*
6. Vent pipe *✓*
7. Fuel pipe *✓*
8. *✓*
9. *✓*
10. *✓*
11. *✓*
12. *✓*
13. *✓*
14. *✓*
15. *✓*
16. *✓*
17. *✓*
18. *✓*
19. *✓*
20. *✓*
21. *✓*
22. *✓*
23. *✓*
24. *✓*
25. *✓*
26. *✓*
27. *✓*
28. *✓*
29. *✓*
30. *✓*
31. *✓*
32. *✓*
33. *✓*
34. *✓*
35. *✓*
36. *✓*
37. *✓*
38. *✓*
39. *✓*
40. *✓*
41. *✓*
42. *✓*
43. *✓*
44. *✓*
45. *✓*
46. *✓*
47. *✓*
48. *✓*
49. *✓*
50. *✓*
51. *✓*
52. *✓*
53. *✓*
54. *✓*
55. *✓*
56. *✓*
57. *✓*
58. *✓*
59. *✓*
60. *✓*
61. *✓*
62. *✓*
63. *✓*
64. *✓*
65. *✓*
66. *✓*
67. *✓*
68. *✓*
69. *✓*
70. *✓*
71. *✓*
72. *✓*
73. *✓*
74. *✓*
75. *✓*
76. *✓*
77. *✓*
78. *✓*
79. *✓*
80. *✓*
81. *✓*
82. *✓*
83. *✓*
84. *✓*
85. *✓*
86. *✓*
87. *✓*
88. *✓*
89. *✓*
90. *✓*
91. *✓*
92. *✓*
93. *✓*
94. *✓*
95. *✓*
96. *✓*
97. *✓*
98. *✓*
99. *✓*
100. *✓*

*Light outlet in smoke pipe
Chimney has clean out.
V.A.*



FILL IN AND SIGN WITH INK

01084

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Dec. 2, 1982

PERMIT ISSUED

DEC 3 1982

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 474 Deering Avenue Use of Building multi family -3 No Stories 2 New Building Existing " x
Name and address of owner of appliance Elaine Harper - same
Installer's name and address Ballard OIL & Equip- 135 Marginal Way Telephone 772-1991

General Description of Work

To install Steam boiler & burner unit - replacement

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? # 2 fuel oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 4' all around
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue 12 x 12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Carlin - gun Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2
Location of oil storage basement Number and capacity of tank 275 gal.
Low water shut off yes Make McDonald Miller No. 67
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 275 gal.

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 15.00

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

CS 300

INSPECTION COPY

Signature of Installer

(2) Mr. Carroll

NOTES

Permit No. 32/1084
 Location 177 C. M. W. Ave.
 Owner Electric Company
 Date of permit 12-2-82
 Approved 12-3-82

1. 1 1/2" FILL PIPE
2. 1 1/2" VENT PIPE
3. Kind of Seal
4. Burner Rigidity & Support
5. Name & Label
6. Control
7. High Limit Control
8. Main Gas Switch
9. Low Water Cut-off
10. High Limit Control
11. Flue Gas Support & Protection
12. Valves in Supply Line
13. Control of Tanks
14. Tank Rigidity & Support
15. Oil Tank
16. Instruction Card
17. Oil Tank
18. Exhaust Ventilation
19. Smokeproof to combustible
20. Thermal Control switch



FILL IN AND SEND WITH DAK

01084

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Dec. 7, 1932

PERMIT ISSUED

DEC 8 1932

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned her by applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 474 Deering Avenue of Building multi family -3 No. Stories 2 New Building Existing
Name and address of owner of appliance Elaine Harper - same
Installer's name and address Pallard OIL & Lube- 135 Marginal Way Telephone 772-1991

General Description of Work

To install steam boiler burner unit - replacement

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? # 2 fuel oil
Minimum distance from material, from top of appliance or casing top of furnace 4' all around
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue 12 x 12 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour yes
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Carlin - gun Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/2"
Location of oil storage basement Number and capacity of tanks 275 gal.
Low water shut off yes Make McDonald Miller No. 67
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 275 gal.

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smoke pipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 15.00

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

CS 300

INSPECTION COPY

Signature of Installer

W. M. Carroll

Permit No. 82/1084
 Location 478 C. M. W. Ave.
 Owner Clair M. W. W.
 Date of permit 12-2-82
 Approved 12-5-82

1. 1/2" FILL PIPE
2. 1/4" VENT PIPE
3. Kind of Heat
4. Burner Rigidty & Support
5. Name & Label
6. Control
7. High Limit Control
8. Low Water Cutoff
9. High Limit Control
10. High Limit Control
11. Burner support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction Card
17. Oil leaks
18. Adequate ventilation
19. Smokeproof to combustible
20. Thermal Control switch



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date February 9, 1989
Receipt and Permit number 00030

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 470 Deering Avenue

OWNER'S NAME: Carolyn Treat (Customer) ADDRESS: same

	FEES
OUTLETS:	
Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	
SERVICES:	
Overhead ☒ Underground _____ Temporary _____ TOTAL amperes <u>100</u> ..	3.00
METERS: (number of) <u>1</u> ..	.50
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of units) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate units) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____

TOTAL AMOUNT DUE: 5.00

INSPECTION: 9:30 a.m.
Will be ready on Feb. 13, 1989; or Will Call _____
CONTRACTOR'S NAME: Henryk Gonia
ADDRESS: 2 Laurel Ave., Auburn, ME
TEL.: 783-7720
MASTER LICENSE NO.: 10771 SIGNATURE OF CONTRACTOR: [Signature]
LIMITED LICENSE NO.: _____

ELECTRICAL INSTALLATIONS -

INSPECTIONS: Service 100 amp by Russo
 Service called in 2/14/89
 Closing-in _____ by _____

PROGRESS INSPECTIONS:

_____/_____/_____
 _____/_____/_____
 _____/_____/_____
 _____/_____/_____
 _____/_____/_____
 _____/_____/_____

Permit Number C10030
 Location 470 E. Irving Avenue
 Owner Charles J. T. T. T.
 Date of Permit 2/9/89
 Final Inspection 2/14/89
 By Inspector (Signature)
 Permit Application Register Page No. 56

DATE:

REMARKS:

2/14/89 This has two service drops to one building - No determination could be made if the building is frequented between both occupancies - Since this is an existing situation I have directed the electrician to comply with the 2nd sentence of Article 230.2 1987 edition of N.E.C. which requires a permanent mark or plaque at each service location - Compliance will be accomplished by weekly inspections to make sure this is accomplished



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date February 9, 1989
Receipt and Permit number 00030

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 470 Deering Avenue

OWNER'S NAME: Carolyn Treat (Customer) ADDRESS: same

FEEs

OUTLETS:

Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____

FIXTURES: (number of)

Incandescent _____ Fluorescent _____ (not strip) TOTAL _____

Strip Fluorescent _____ ft. _____

SERVICES:

Overhead ☒ Underground _____ Temporary _____ TOTAL amperes 100 .. 3.00

METERS: (number of) 1 .. .50

MOTORS: (number of) _____

Fractional _____

1 HP or over _____

RESIDENTIAL HEATING:

Oil or Gas (number of units) _____

Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler) _____

Oil or Gas (by separate units) _____

Electric Under 20 kws _____ Over 20 kws _____

APPLIANCES: (number of)

Ranges _____ Water Heaters _____

Cook Tops _____ Disposals _____

Wall Ovens _____ Dishwashers _____

Dryers _____ Compactors _____

Fans _____ Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of)

Branch Panels _____

Transformers _____

Air Conditioners Central Unit _____

Separate Units (windows) _____

Signs 20 sq. ft. and under _____

Over 20 sq. ft. _____

Swimming Pools Above Ground _____

In Ground _____

Fire/Burglar Alarms Residential _____

Commercial _____

Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____

over 30 amps _____

Circus, Fairs, etc. _____

Alterations to wires _____

Repairs after fire _____

Emergency Lights, battery _____

Emergency Generators _____

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT

DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b)

TOTAL AMOUNT DUE: 5.00

INSPECTION: 9:30 a.m.

Will be ready on Feb. 13, 1989; or Will Call _____

CONTRACTOR'S NAME: Henryk Gonja

ADDRESS: 2 Laurel Ave.

TEL: 783-7720

MASTER LICENSE NO.: 10771

LIMITED LICENSE NO.: _____

CONTRACTOR: 60

ELECTRICAL INSTALLATIONS -

Permit Number 00080
 Location 470 Locum Avenue
 Owner Carlyle, Ltd.
 Date of Permit 2/9/87
 Final Inspection 2/14/87
 By Inspector [Signature]
 Permit Application Register Page No. 56

INSPECTIONS: Service 100 amp by [Signature]
 Service called in 2/14/87
 Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____
 _____ / _____ / _____

DATE:	REMARKS:
2/14/87	this has two service drops to one building. No determination could be made if the building is foreclosed. Between both occupancies - since this is a spitting situation I have directed the electrician to comply with the 2nd sentence of Article 230.2 1987 edition of N.E.C. which requires a permanent mark or plaque at each service location - Compliance will be enforced by weekly inspections to make sure this is accomplished.