


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

November 17, 2017

Responsible Party 1: GILLIES CHRISTINA 56 LINCOLN ST PORTLAND, ME 04103		
Location 56 LINCOLN ST	CBL 125 D008001	Inspection Date 10/24/2017
Inspector Stephen Nee	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 12/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 720- 5.5.6.1 CO ALARMS REQUIRED; The performance, location, and mounting of notification appliances used to initiate or direct action, evacuation or relocation of the occupants, or for providing information to occupants or staff, shall comply with the requirements of Chapter 6. Co alarms are needed in all apartment.	IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed.
NFPA 101- 7.1.3.2.1 60-MIN FIRE DOOR ASSEMBLIES REQ; The separation shall have a minimum 1-hour fire resistance rating where the exit connects three or fewer stories. Third floor apartment needs fire rated doors in both front and rear entrances	2/1/18
NFPA 101- 31.3.4.5.1 SMOKE DETECTOR EACH SLEEPING ROOM; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements. No smoke detector in 1st floor apartment bedrooms	2/1/18
NFPA 1, CHAPTER 10 - 10.11.6 HIBACHI OR GRILL ON BALCONY; NO HIBACHI, GAS-FIRED GRILL, CHARCOAL GRILL, OR OTHER SIMILAR DEVICES USED FOR COOKING, HEATING, OR OTHER PURPOSE, SHALL BE USED OR KINDLED ON ANY BALCONY OR UNDER ANY OVERHANG PORTION OR WITHIN 10 FTOF ANY STRUCTURE grills on the first and third floor decks	12/8/17
FINAL DATE OF COMPLETED VIOLATION(S)	2 / 1 / 18
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	2 / 15 / 18

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

12/8/17
Date

Christopher P. Dillie
Responsible Party

Date

Responsible Party

SEEN AND AGREED

12/12/2017
Date

CAPT. JEB
Fire Prevention Bureau