



Jeff Levine, AICP, Director  
Planning & Urban Development Department

Ann Machado  
Zoning Administrator

### NFPA LIFE SAFETY CODE – FIRE PREVENTION CODE DWELLING UNIT COMPLIANCE

Section 14-391 of the Land Use Ordinance allows illegal non-conforming dwelling units to become legalized through a given process. Part of this process is that the dwelling units that are requested to be legalized MUST comply, or be able to comply, with the NFPA Life Safety Code – Fire Prevention Code, PRIOR to issuing the requested permit.

Please return this form to the Zoning Administrator as to compliance or the ability to comply with these codes.

Location: 514 Deering Ave 125-E-006

Owner: East End Corp Skia Whillier

Address of owner: PO Box 10291, Portland ME 04104 879-6081  
(If different)

Applicant Information: \_\_\_\_\_  
(If different):

Current number of legal units: eight (8)

Number of units to be legalized: one (1)  
total: nine (9)

Comments of approval or disapproval (List any and all conditions):

- Fire Doors are required (Several locations)
- lighter (Dryer in front hallway will require 1 hour separation)
- Hardwired battery back-up smoke and CO detection required in several units and hallways.

Signature: [Signature] Date: 9/21/2015