

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

March 28, 2018

**THE PORTLAND JEWISH FUNERAL HOME
 471 DEERING AVE
 PORTLAND ME 04103**

Location: Levey Chapel 471 DEERING AVE	CBL 125 J002001	Inspection Date 2/16/2018
Inspector Dale Dyer	Inspection Type FP Routine Inspection Commerci	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must remedy each violation by the date of re-inspection.

Your failure to complete the violations by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE; The owner or designated agent or occupant of a property in which fire extinguishers are located shall be responsible for inspection, maintenance, and recharging. Throughout the building.	5/04/2018
NFPA 101- 7.9.2.7 EMERGENCY LIGHTS NOT WORKING; The emergency lighting system shall be either continuously in operation or shall be capable of repeated automatic operation without manual intervention. Chapel, hallway, and at the bottom of the stairs.	5/04/2018
FINAL DATE OF COMPLETED VIOLATION(S)	___ 5 / 04 / 2018
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S) This reinspection is scheduled for 5/4/18 @ 9:30am	___ / ___ / ___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date Responsible Party

Date Responsible Party

SEEN AND AGREED

Date Fire Prevention Bureau