


CITY OF PORTLAND
FIRE PREVENTION BUREAU
380 Congress Street, Portland, Maine 04101
fireprevention@portlandmaine.gov
(207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

April 20, 2017

Responsible Party 1: TASA LIMITED LIABILITY COMPANY 510 CANAL ST LEWISTON, ME 04240		
Location 570 FOREST AVE	CBL 125 J018001	Inspection Date 4/3/2017
Inspector John Cenate	Inspection Type FP Routine Inspection Commerci	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 5/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method.	5/9/2017
FINAL DATE OF COMPLETED VIOLATION(S)	5/9/17
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

All extinguishers have now been re-inspected by 3RD PARTY (ADMIRAL - SCARBOROUGH) AND RE-TAGGED; CHECKLIST IS KEPT ON FILE AT OUR MAIN OFFICE IN LEWISTON.

Steven Shaver
STEVEN SHAVER

Owner / LANDLORD

Received

CAPT. JES 17