



Permitting and Inspections Department
Michael A. Russell, MS, Director

June 30, 2017

BAO BAO INVESTMENTS LLC
175 MIDDLE RD
FALMOUTH, ME 04105

CBL: 125 K004001
Located at: 28 LINCOLN ST

Certified Mail 7014 1820 0001 4047 0904

Dear BAO BAO INVESTMENTS LLC,

An evaluation of the above-referenced property on **06/30/2017** shows that the structure fails to comply with Chapter 6, Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within **30** days of the date of this notice. A re-inspection of the premises will occur on **08/02/2017** at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Sincerely,

/s/

A handwritten signature in black ink, appearing to read "Jason Duval", written over a horizontal line.

Jason Duval
Code Enforcement Officer

**CITY OF PORTLAND
HOUSING SAFETY OFFICE**

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager BAO BAO INVESTMENTS LLC		Inspector Jason Duval	Inspection Date 6/30/2017
Location 28 LINCOLN ST	CBL 125 K004001	Status Violations Exist	Inspection Type Bed Bugs

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 55.05

Violation: NFPA 720- 5.5.6.1 CO ALARMS REQUIRED; The performance, location, and mounting of notification appliances used to initiate or direct action, evacuation or relocation of the occupants, or for providing information to occupants or staff, shall comply with the requirements of Chapter 6.

Notes: Address missing CO alarm on first floor and basement.

2) 55.051

Violation: NFPA 101- 7.2.1.8.1 DOORS SHALL BE SELF-CLOSING & SELF-LATCHING; A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise specified by 7.2.1.8.3.

Notes: Repair fire door hinges. Address missing deadbolt for fire door to basement.

3) 55.160

Violation: NFPA 101- 31.3.4.5.1 SMOKE DETECTOR VIOLATION; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms on all levels of the dwelling unit, including basements.

Notes: Address missing smoke alarms in bedrooms throughout the dwelling and repair hanging smoke alarms.

4) 6-109.(e)

Violation: RODENT AND VERMIN CONTROL.; Every dwelling, dwelling unit, rooming house, rooming unit, and dwelling premises shall be kept and maintained free from insects, rodents, or other pests in accordance with the following division of responsibility.

(a.)Every occupant of a dwelling unit shall be responsible for the extermination of such insects, rodents, or other pests where the infestation is confined to such dwelling unit, except as provided in subsection 6- 109(5)b.

(b.)When infestation of a dwelling unit shall exist because of the failure of the owner or operator of a dwelling or dwelling premises to keep the same in a substantially rodent or vermin-proof condition, extermination shall the responsibility of the owner or operator.

(c.)Every owner or operator of a dwelling shall be responsible for the extermination of such insects, rodents, or other pests whenever infestation exists in any two (2) or more dwelling and/or rooming units, or in shared areas or upon the dwelling premises.

(d.)Every owner or operator of a rooming house shall be responsible for the extermination of any insects, rodents, or other pests in the dwelling or upon the dwelling premises.

Notes: A licensed pest control company required for bed bugs. A treatment report must be shown to inspector.
