

INSPE

PF



APPLICATION FOR PERMIT

DEPARTMENT OF BUILDING INSPECTIONS SERVICES

ELECTRICAL INSTALLATIONS

Date June 27, 1988, 19
Receipt and Permit number 29286

To the C E ELECTRICAL INSPECTOR, Portland, Maine:
The assigned hereby applies for a permit to make electrical installations in accordance with the laws of
Maine, Portland Electric, 1000 Congress Ave. the National Electrical Code and the following specifications:
LOCAT OF WORK: ADDRESS: 655 Congress (Rice)
OWNE NAME: Jeff Rice J. Allen (tenant)

		FEES	
OUT	S: Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL 1-30 _____		
FIX	RES: (number of) Incandescent 2 _____ Fluorescent _____ (not strip) TOTAL 1-10 _____		3.00
	Strip Fluorescent _____ ft. _____		3.00
S	VICES: Overhead x _____ Underground _____ Temporary _____ TOTAL amperes 200 _____		.50
	FERS: (number of) 1 _____		
	TORS: (number of) _____		
	Fractal _____		
	1 HF or over _____		
	RESIDENTIAL HEATING: Oil or Gas (number of units) _____		
	Electric (number of rooms) _____		
	COMMERCIAL OR INDUSTRIAL HEATING: Oil or Gas (by a main boiler) _____		
	Oil or Gas (by separate units) _____		5.00
	Electric Under 20 kws x _____ Over 20 kws _____		
APPLIANCES:	(number of) 1 _____	Water Heaters _____	
	Ranges _____	Disposals _____	
	Cook Tops _____	Dishwashers 1 _____	
	Wall Ovens _____	Compactors _____	
	Dryers _____	Others (denote) _____	4.50
	Fans 1 _____		
	TOTAL 3 _____		
MISCELLANEOUS:	(number of) _____		1.00
	Branch Panels 1 _____		
	Transformers _____		
	Air Conditioners Central Unit _____		
	Separate Units (windows) _____		
	Signs 20 sq. ft. and under _____		
	Over 20 sq. ft. _____		
	Swimming Pools Above Ground _____		
	In Ground _____		
	Fire/Burglar Alarms Residential _____		
	Commercial _____		
	Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____		
	over 20 amps _____		
	Circus, Fairs, etc. _____		
	Alterations to wires _____		
	Repairs after fire _____		.50
	Emergency Lights, battery 1 _____		
	Emergency Generators _____		
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT		INSTALLATION FEE DUE:	
FOR REMOVAL OF A "STOP ORDER" (304-16.b)		DOUBLE FEE DUE:	
		TOTAL AMOUNT	20.50

INSPECTION: Will be ready on June 29, 1988; or Will Call _____
CONTRACTOR'S NAME: Alan Eger Electric
ADDRESS: P.O. Box 238 Corham, Me 04038-0238
TEL: 854-4846
MASTER LICENSE NO.: 4590
LIMITED LICENSE NO.: _____
SIGNATURE OF CONTRACTOR: *Alan Eger*

INSPECTOR'S COPY — WHITE
OFFICE COPY — CANARY
CONTRACTOR'S COPY — GREEN



Z

Inspection Record

[illegible]

OR - CHARGE of USE

Ag. Allen

Date 7-6-88

PERMIT # 100814

FOR PORTLAND BUILDING PERMIT APPLICATION

MAP # LOT #

For Official Use Only

DATE

Place fill out any part which applies. Proper plans must accompany form.

DATE JULY 6, 1988

Address: 180 Woodford St., Portland, ME 04102

Subdivision: Yes / No

LOCALITY OF CONSTRUCTION: 543 Deering Avenue

Name: _____

CONTRACTOR: owner

Permit Expiration: _____

ADDRESS: _____

Valuation: _____

Est. Construction Cost: \$7,000

1. Ceiling Joist Size: _____

Permit Use: _____

2. Ceiling Strapping Size: _____

Is Proposed Use: _____

3. Type Ceiling: _____

CONTRACTOR'S EXPLANATION OF ANY VARIATIONS IN PERMIT PLANS

4. Insulation Type: _____

COMPLETION DATE ONLY IF THE NUMBER OF UNITS WILL CHANGE

5. Ceiling Height: _____

Of Dwelling Units: _____

6. Roofing Type: _____

Foundation:

7. Roof Covering Type: _____

1. Type of Soil: _____

8. Other: _____

2. Set Backs - Front _____

9. Other: _____

3. Foundation Size: _____

10. Other: _____

4. Other: _____

11. Other: _____

5. Other: _____

12. Other: _____

6. Other: _____

13. Other: _____

7. Other: _____

14. Other: _____

8. Other: _____

15. Other: _____

9. Other: _____

16. Other: _____

10. Other: _____

17. Other: _____

11. Other: _____

18. Other: _____

12. Other: _____

19. Other: _____

13. Other: _____

20. Other: _____

14. Other: _____

21. Other: _____

15. Other: _____

22. Other: _____

16. Other: _____

23. Other: _____

17. Other: _____

24. Other: _____

18. Other: _____

25. Other: _____

19. Other: _____

26. Other: _____

20. Other: _____

27. Other: _____

21. Other: _____

28. Other: _____

22. Other: _____

29. Other: _____

23. Other: _____

30. Other: _____

24. Other: _____

31. Other: _____

25. Other: _____

32. Other: _____

26. Other: _____

33. Other: _____

27. Other: _____

34. Other: _____

28. Other: _____

35. Other: _____

29. Other: _____

36. Other: _____

30. Other: _____

37. Other: _____

31. Other: _____

38. Other: _____

32. Other: _____

39. Other: _____

33. Other: _____

40. Other: _____

34. Other: _____

41. Other: _____

35. Other: _____

42. Other: _____

36. Other: _____

43. Other: _____

PERMIT 000814 CITY OF Portland BUILDING PERMIT APPLICATION MAY # 1017

Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Jay Allen and Gary Robbins

Address: 180 Woodford St., Portland 04102

LOCATION OF CONSTRUCTION 543 Deering Avenue

CONTRACTOR: owner SUBCONTRACTORS: 772-4023

ADDRESS:

Est. Construction Cost: \$2,000 Type of Use: repair shop

Permit Use:

Building Dimensions: L. W Sq. Ft. Stories L. Side

Is Proposed Use: Signal Condominium Apartment

Change use from repair shop to restaurant

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

Residential Buildings Only: 1 OF Dwelling Units

OF No. Dwelling Units

Foundation:

1. Type of Soil:

2. Set Backs: Front Side(s)

3. Footing Size:

4. Foundation Size:

5. Other:

Floor:

1. Sills Size:

2. Girder Size:

3. Lally Column Spacing:

4. Joist Size:

5. Bridging Type:

6. Floor Sheathing Type:

7. Other Material:

8. Sills in 3rd br anchored.

Exterior Walls:

1. Studding Size:

2. No. windows:

3. No. Doors:

4. Header Sizes:

5. Bracing:

6. Corner Posts Size:

7. Insulation Type:

8. Sheathing Type:

9. Siding Type:

10. Masonry Materials:

11. Metal Materials:

Interior Walls:

1. Studding Size:

2. Header Sizes:

3. Wall Covering Type:

4. Fire Wall If required:

5. Other Materials:

Date: July 6, 1988

Index Five Lines:

Block Code:

Year Limit:

Estimated Cost: \$2,000

Value of Structure:

Fee: \$30.00

Submittal: Yes / No

Name:

Lot:

PERMIT

Permit Description:

Overlaid:

Public

UL-8

1531

Celling:

1. Ceiling Joist Size:

2. Ceiling Strapping Size:

3. Type Ceiling:

4. Insulation Type:

5. Ceiling Height:

6. Ceiling Finish:

Roof:

1. Truss or Rafter Size:

2. Sheathing Type:

3. Roof Covering Type:

4. Other:

Chimneys:

Type:

Number of Fire Places:

Heating:

Type of Heat:

Electrical:

Service Entrance Size:

Smoke Detector Required:

Plumbing:

1. Approval of soil test if required:

2. No. of Toilets or Showers:

3. No. of Sinks:

4. No. of Lavatories:

5. No. of Other Fixtures:

Swimming Pools:

1. Type:

2. Pool Size:

3. Must conform to National Electrical Code and State Law.

Zoning:

District:

Street Frontage Req.:

Required Setback: Front Back Side

Revised Required:

Zoning Board Approval: Yes No

Planning Board Approval: Yes No

Conditional Use: Variance

Shore and Floodplain Mgmt:

Other: (Explain)

Date approved:

Permit Received By: Nancy L. Dzema

Signature of Applicant: Jay Allen

Signature of CEO: White Tag-CEO

Inspection Dates: White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Yellow-GPCOG

White Tag-CEO

Copyright GPCOG 1987

PERMIT # _____ CITY OF Portland BUILDING PERMIT APPLICATION

MAP # _____ LOT # _____

For Official Use Only

Owner: Jay Allen and Gary Robbins

Date: July 6, 1988

Address: 180 Woodford St., Portland 04102

Subdivision: Yes / No

LOCATION OF CONSTRUCTION: 543 Deering Avenue

Permit Issued: Public

CONTRACTOR: owner SUBCONTRACTORS: 772-4023

Valued Structure: Yes \$30,000

ADDRESS: _____

City of Portland

Est. Construction Cost: \$2,000

1. Ceiling Joists Size: _____

Permit Use: _____

2. Ceiling Strapping Size: _____

Building Dimensions: L _____ W _____ Sq. Ft. _____

3. Type Collage: _____

Is Proposed Use: _____

4. Insulation Type: _____

Conversion: Explain with renovations as per plans.

5. Ceiling Height: _____

COMPLETE ONLY IF THE NUMBER OF UNITS WILL CHANGE

1. Truss or Joist Size: _____

of Dwelling Units: _____

2. Sheathing Type: _____

Foundation: _____

3. Roof Covering Type: _____

1. Type of Soil: _____

4. Other: _____

2. Set Backs - Front: _____

5. Chimneys: _____

3. Footings Size: _____

Heating: _____

4. Foundation Size: _____

Electric: _____

5. Other: _____

Plumbing: _____

1. Sills Size: _____

1. Approval of soil test if required: _____

2. Gird Size: _____

2. No. of Tubes or Showers: _____

3. Lally Column Spacing: _____

3. No. of Lavatories: _____

4. Joists Size: _____

4. No. of Other Fixtures: _____

5. Bridging Type: _____

Swimming Pools: _____

6. Floor Sheathing Type: _____

1. Type: _____

7. Other Material: _____

2. Pool Size: _____

3. Must conform to National Electrical Code and State Law.

Zoning: _____

Review: _____

Permit Received By: Nancy L. Deema

Signature of Applicant: _____

Signature of CEO: _____

Inspection Dates: _____

White-Tax Assessor Yellow-CPOCC White Tag-CEO

© Copyright GPCOG 1987



CITY OF PORTLAND, MAINE

389 CONGRESS STREET
PORTLAND, MAINE 04101
(207) 775-5451

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

P. SAMUEL HOFFSES, CHIEF
INSPECTION SERVICES DIVISION

July 8, 1988

Allen & Robbins
180 Woodford Street
Portland, Maine 04102

Re: 543 Deering Avenue, Portland, Maine

Dear Sirs:

Your application to change the use of 543 Deering Avenue from a repair shop to a restaurant has been reviewed and a permit is herewith issued subject to the following requirements:


1. The total occupant load shall not exceed 49 people.
2. No part of this establishment, including bathrooms shall be more than 50 feet from the exit door measured along the aisle and corridor and including the stairways.
3. An approved hood system shall be provided in accordance with NFPA 96 standards.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services

cc: Lt. Collins, Fire Prevention



[illegible]

513 DEERING AVE



BASEMENT

DEPT OF BUILDING INSPECTIONS
CITY OF PORTLAND

JUL 06 1988

RECEIVED

