



P.O. BOX 1355 • AUBURN, MAINE 04211-1355

**TELEPHONE**  
(207) 784-7525  
(800) 424-3900  
(800) 538-3473

**FAX**  
(207) 777-6210

**EMAIL**  
firesafe@fire-safe.com

**WEBSITE**  
firesafeequipment.com

March 21, 2019

Portland Fire Department  
Attn: Mike Clinton Fire Alarm Technician  
380 Congress Street  
Portland, Maine 04101

RE: Maiz

Per your request, let this letter serve as our certification for completion of the installation on a 4-gallon Range Guard Wet chemical fire suppression systems for Maiz located at 621 Forest Avenue in Portland, Maine 04101.

Puff test performed has passed and system armed.

Installation of the system was done in accordance with NFPA 96 Standards and meets UL 300 guidelines.

This system is setup for bi-annual inspection: **February & August.**

If you have any further questions or require additional information, Please feel free to call 207-784-7525.

Sincerely,

A handwritten signature in blue ink that reads "Eileen Lord".

Eileen Lord  
Associate

**“PROTECTING  
YOUR  
ASSETS”**

PRE-ENGINEERED  
RESTAURANT SYSTEMS

ENGINEERED SYSTEMS  
COMMERCIAL & INDUSTRIAL

PORTABLE  
FIRE EXTINGUISHERS  
SALES & SERVICE

HYDROSTATIC  
CYLINDER TESTING



P.O. BOX 1355 • AUBURN, MAINE 04211-1355

**TELEPHONE**  
(207) 784-7525  
(800) 424-3900  
(800) 538-3473

**FAX**  
(207) 777-6210

**EMAIL**  
firesafe@fire-safe.com

**WEBSITE**  
firesafeequipment.com

March 21, 2019

Portland Fire Department  
Attn: Mike Clinton Fire Alarm Technician  
380 Congress Street  
Portland, Maine 04101

RE: Woodfords Social Club

Per your request, let this letter serve as our certification for completion of the installation on a 4-gallon Range Guard Wet chemical fire suppression systems for **Woodfords Social Club** located at 179 Woodfords Street in Portland, Maine 04101.

Puff test performed has passed and system armed.

Installation of the system was done in accordance with NFPA 96 Standards and meets UL 300 guidelines.

This system is setup for bi-annual inspection: **March & September.**

If you have any further questions or require additional information, Please feel free to call 207-784-7525.

Sincerely,

Eileen Lord  
Associate

**“PROTECTING  
YOUR  
ASSETS”**

PRE-ENGINEERED  
RESTAURANT SYSTEMS

ENGINEERED SYSTEMS  
COMMERCIAL & INDUSTRIAL

PORTABLE  
FIRE EXTINGUISHERS  
SALES & SERVICE

HYDROSTATIC  
CYLINDER TESTING