




Reviewed for Code Compliance
 Permitting and Inspections Department
 Approved with Conditions
 03/30/2020



Design Team
 Lisa White
 Workplace Transformation Facilitation
 Portland Maine
 phone: (207) 329-2189
 email: lsa@workplacef.com

Josef Chalat,
 Maine Registered Architect
 PO Box 6383
 Cape Elizabeth, Maine 04107
 phone: (207) 318-3234
 email: aznu@blu@gmail.com

Tenant
 United Way of Greater
 Portland
 One Canal Plaza, Suite 300

Contractor
 Name
 company name
 Address
 phone:
 email:

Building Owner
 Dirigo Realty

Project Address
 550 Forest Avenue
 Portland Maine, 04101
 City of Portland
 126 A007001
 B2b Zoning District

Dates and Revisions
 11/22/2019 Permit Set

Drawing Title

Proposed Life Safety Plan

Sheet Number

LS1.1



- Life Safety Device Symbols**
- [F] fire alarm pull station mounted at 48" AFF
all units shown are existing
 - [EX] horn/strobe with candela rating indicated: no designation = 15 candela
 - [K3S] strobe with candela rating indicated: no designation = 15 candela
 - [X] exit sign
 - [X] exit sign with integral emergency light
 - [SD] smoke detector - photo electric addressable
 - [OS] occupancy sensor
 - [E] ceiling mounted emergency light: DUAL LITE EV4R, recessed ceiling mount with 90 minute illumination backup power
 - [R] emergency light remote head
 - [FE] fire extinguisher
 - [KP] key pad
 - [WR] wireless router
 - [FACP] fire alarm control panel

EX Existing

Existing equipment; provide new devices as required to match existing devices



Life Safety Device Plan
 1/8" = 1'-0"

