Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/20/15

R-VALUES		
ASSEMBLY	REQUIRED	PROPOSED
-ROOF	49	51.5
-FLOOR	30	N/A
-WALLS	20	24.5
-BASEMENT WALLS	10	14

1 WALL SECTION
3/8" = 1'-0"

0 1'-4" 2'-8" 5'-4"

SCALE: 3/8" = 1'-0"

SECTIONS

CABOT

DATE: 11.18.2014

DRAWN BY: BB

A3.1

PROSPECT
DESIGN
58 FORE ST. PORTLAND, ME
www.prospectdesign.me
T: 207 - 749 - 7400