

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ANNANDALE HOLDINGS LLC

Located at

583 FOREST AVE (2nd & 3rd floor)

PERMIT ID: 2018-00285

ISSUE DATE: 04/09/2018

CBL: 126 E016001

has permission to **Fit up space for tattoo studio -Stripping and refinishing existing walls, new flooring, 14 new windows for second floor and attic. Finish attic space for storage only.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

second floor - personal service (tattoo studio) & third floor storage for the 2nd floor

Building Inspections

Use Group: B, S **Type:** 5B
2 Story Mixed use w/ attic
Un-sprinkled
occupant load for 2nd unit: 15
2 & 3
2009 IBC / MUBEC

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Close-in Plumbing/Framing

Electrical - Commercial

Final - Electric

Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2018-00285	Date Applied For: 03/05/2018	CBL: 126 E016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Personal Services/Tattoo studio 2nd floor & storage 3rd floor		Proposed Project Description: Fit up space for tattoo studio -Stripping and refinishing existing walls, new flooring, 14 new windows for second floor and attic. Finish attic space for storage only.		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 03/16/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note: B2b zone tattoo parlor is personal service -permitted under section 14-182 - all work is within the existing footprint				
Conditions:				
1) Separate permits shall be required for any new signage.				
2) With the issuance of this permit and the certificate of occupancy, the use of the second floor shall remain personal service and the third floor shall remain storage. Any change of use shall require a separate permit application for review and approval.				
3) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.				
4) This permit is being approved on the basis of plans and documents submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspection	Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 04/09/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) All construction shall comply with City Code Chapter 10.				
3) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code				
4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS	Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 03/28/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 04/09/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Per the 2010 Americans with Disabilities Act, business must remove architectural barriers in existing building that are readily achievable. Readily achievable means easily accomplishable without much difficulty or expense. This requirement is based on the size and resources of a business. So, business with More resources are expected to remove more barriers than business with fewer resources.				
2) The means of egress shall be illuminated and marked in accordance with 2009 NFPA 101, sections 7.8 and 7.10.				
3) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8.				

PERMIT ID: 2018-00285

Located at: 583 FOREST AVE (2nd & 3rd

CBL: 126 E016001

- 4) A separate City of Portland Water-Based Fire Suppression System Permit is required for all new sprinkler systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.
- 5) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
If applicable, all outstanding code violations shall be corrected prior to final inspection.