

2/10/2012
1st NOV sent.

COMPLAINT PROCESSING

Complaint Information:

Address: 52 Melrose St
CBL: 126 F010
Case # 2012-02-324/6
Reporting Party/# Mike Denney
Landlord/Contact/# Ralph Hughes

Complaint(s):

Chimney top 5 courses
falling down - need to
be secured

Property Information:

Owner/LLC
Address

Ralph Hughes
29 Mason Dr.
Hollis Ctr. ME
041042

Inspection Information:

Inspection Date
Inspector
Assisting
Units in Bldg
Units Allowed

2/8/2012
GF
Ø
1
1

Work done 2/13/12
G.C. removed loose courses
+ epoxy grouted missing
pointing

When did this first occur? _____

How many times? _____

Have you notified LL _____

G.C. 232-8134

Tom Blackburn

Closed 2/14/12