City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716 Permit No: 980909 Location of Construction: Phone: Owner: 774-2276 Daniel & Lucy Marshall 28 Covle St Owner Address: Lessee/Buyer's Name: Phone: BusinessName: 04101 SAA Permit Issued: Address: Phone: Contractor Name: AUG 1 8 1998 Bob Davenport COST OF WORK: Proposed Use: PERMIT FEE: Past Use: 6,000.00 50.00 **FIRE DEPT.** □ Approved INSPECTION: 1-fam ☐ Denied Use Groups CBL: 126-I-007 Signature: Proposed Project Description: PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved Approved with Conditions: □ Shoreland /\\\ New Front Steps & Covered Stoop Denied □ Wetland ☐ Flood Zone Signature: Date: □ Subdivision ☐ Site Plan mai ☐minor ☐mm ☐ Permit Taken By: MN 10 August 1998 **Zoning Appeal** □ Variance This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules. ☐ Miscellaneous Building permits do not include plumbing, septic or electrical work. ☐ Conditional Use 3. Building permits are void if work is not started within six (6) months of the date of issuance. False informa-☐ Interpretation ☐ Approved tion may invalidate a building permit and stop all work.. □ Denied **Historic Preservation** □ Not in District or Landmark PERMIT ISSUED WITH REQUIREMENTS Does Not Require Review ☐ Requires Review Action: **CERTIFICATION** ☐ Appoved I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been □ Approved with Gonditions □ Denied authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit 11 August 1998 SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE: RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT

2

COMMENTS

Stairs are Birch w/ grante Treats	ome to Close in on Plent 02:0461
Stain a Birch woon to Track	Day Die (00, 0,00,60 com)
To all is in the state of the s	thinking (piece cours of wood)
Toplanding is 42" from grade - no	quaids no quaids down
Siles - no handiards - risers non	setion 7 1/2" to 81/2"
Siles - no handials - users con- troods ch @ 13" - wealth of trea	es come from 91to 91/2"
high due by Md 41 f o	- 10 plant 1 = 116
Work done by M& M Landscoping	
	Inspection Record
	Type Date
	ndation:
	ning:
	mbing:
	d:
Othe	er.

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application Additions/Alterations/Accessory Structures To Detached Single Family Dwelling

SEND TO-

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or

OTE**If you or the property owner ow City, payment arran			axes or user charges on its of any kind are accep	
Location/Address of Construction 28	Coyle	5-	PORTLAND	
Owner's Address:	00/	NIEL + LUCY Buyer's Name (If Applica)	7 101 (-1.1)	Telephone#: 774-2276 Of Work Fee
28 Coyle ST			2 1	6000: \$50
Proposed Project Description: (Please be as specific New Front Steps	as possible) + CUVETE	d stoop		A
Contractor's Name. Address & Telephone Daven port			Record By	My JANES
•All Electrical Installation must of •HVAC(Heating, Ventilation and A You must Include the following w 1) A Copy 2) A Co	comply with the 1 dir Conditioning) ith you applicate y of Your Deed opy of your Co 3) A Plot Place, a complete	996 National Electinstallation must callon: I or Purchase austruction Contant (Sample Attoplot plan (Site Plan)	omply with the 1993 BC I'd Sale Agreement Tract, if available ached) an) must include:	hy Section 6-Art III. DCA Mechanical Code. OF PORTLAND, ME AUG 0 1998
 The shape and dimension of the property lines. Structures include pools, garages and any other accessions are specified and required zoning district. 	le decks porches, a cessory structures.	bow windows canti		
	· ·	Plans (Sample A		
A complete set of construction dra Cross Sections w/Framing deta Floor Plans & Elevations Window and door schedules Foundation plans with required Electrical and plumbing layout equipment, HVAC equipment (drainage and dam Mechanical drawi (air handling) or ot	hes, decks w/ railing pproofing ings for any specializ her types of work th	s, and accessory structures and equipment such as fun	s) naces, chimneys, gas
I hereby certify that I am the Owner of recand that I have been authorized by the ow laws of this jurisdiction. In addition, if a pauthorized representative shall have the approvisions of the codes applicable to this	cord of the named point to make this appearmit for work desuthority to enter all	oplication as his/her scribed in this applic	authorized agent. I agree ation is issued, I certify the	to conform to all applicable at the Code Official's
Signature of applicant:	es Ma	whall	Date: 8/	10/98
Building Permit Fee: \$25.0 O:\INSP\CORRESPMN\UGENT\APADSFD\WPD	of the 1st \$100	0.cost plus \$5.00 per	\$1,000.00 construction of	cost thereafter.

BUILDING PERMIT REPORT	
DATE: 0/17/98 ADDRESS: 28 Coyla of	
REASON FOR PERMIT: To reconstruct Porch	
BUTLDING OWNER: LUCY MAYSHELL	
CONTRACTOR:	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
PERMIT APPLICANT: AXEL Berg. INC.	
USE GROUP R-3 BOCA 1996 CONSTRUCTION TYPE 5B	
CONDITION(S) OF APPROVAL	
This Permit is being issued with the understanding that the following conditions are met:	
#1 #7 #2 FB # (O #2 L # = 0	
Approved with the following conditions: #1, #2, #3, #8, #10, #24, #28	
This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.	
8efore concrete for foundation is placed, approvals from the Development Review Coordinator and Inspect	ion Services
must be obtained. (A 24 hour notice is required prior to inspection)	
2.5 Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed sto	one containing
not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of	12 inches
beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher	er than the
bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the	
top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforat	
the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforati	
protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of	f gravel or
crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2	
2.6° Foundations anchors shall be a minimum of 1 1/2" in diameter. 7" into the foundation wall, minimum of 12	"form comers of
From corners of foundation and a maximum 6'o.c. between bolts. (Section 2305.17)	
Frecaution must be taken to protect concrete from freezing. Section 1908.0	
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is pla	icea. I his is
done to verify that the proper setbacks are maintained. 5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be	came mead from
5. Private garages located <u>beneath habitable rooms</u> in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less that	
resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely	
the interior spaces and the artic area by means of $\frac{1}{2}$ inch gypsum board or the equivalent applied to the gard	
inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/199)	
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code.	
National Mechanical Code/1993). Chapter 12 & NFPA 211	(1000001
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 121	4.0 of the city's
building code.	
(8.) Guardrails & Handrails: A guardrail system is a system of building components located near the open side	
walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface	
level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Grou	
l, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of so	
that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental	
would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-	
less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside	diameter of at
least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0)	
Headroom in habitable space is a minimum of 7'6". (Section 1204.0) Stair construction in Use Group R-3) & R-4 is a minimum of 10" tread and 7 3/4" maximum rise) All other	I fea organa
Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise) All other	Ose Broah
munimum 11" tread. 7" maximum rise. (Section 1014.0)	
 The minimum headroom in all parts of a stairway shall not be less than 30 inches. (6' 8") 1014.4 Every sleeping room below the fourth story in buildings of use Groups R and I-I shall have at least one open 	mble window or
12. Every sleeping room below the fourth story in buildings of use Groups R and I-I shall have at least one open exterior door approved for emergency egress or rescue. The units must be operable from the inside without	the use of
exterior door approved for emergency egress or rescue. The must be operable from the fusible without	

not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)

- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
- 14. All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self-closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19 (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate victory of bedrooms
 - In all bedrooms
 - · In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2

- 17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0
- 18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 19. The Sprinkler System shall maintained to NFPA #13 Standard.
- 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 22. The builder of a facility to which Section 4594–C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)

 All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- 25. All requirements must be met before a final Certificate of Occupancy is issued.
- 26. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).

 Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
Mechanical Code/1993). (Chapter M-16) Please read and implement the attached Land Use-Zoning report requirements. Not to exceed or ignirely for

P. Samuel Hoffses, Building Inspector

cc: Lt McDougall, PFD

Marge Schmuckal, Zoning Administrator

