



Ann Machado <amachado@portlandmaine.gov>

15 Longfellow St. - Permit 2017-00308 - legalization permit

David Petruccelli <petruccellid@portlandmaine.gov>
To: Ann Machado <amachado@portlandmaine.gov>
Cc: Chuck Fagone <psf@portlandmaine.gov>

Mon, Apr 10, 2017 at 10:29 AM

Ann,

She needed to install 1 fire door for the first floor unit, side entrance. And to remove some no longer required smoke alarms, because of the new hard-wired ones she installed.

David

Capt. David Petruccelli
Portland Fire Department
Fire Prevention &
Community Outreach Branch
380 Congress St
Portland, ME 04101

Office: [207-874-8400](tel:207-874-8400)
Mobile: [207-400-7488](tel:207-400-7488)
Fax: [208-874-8410](tel:208-874-8410)

[Quoted text hidden]