DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BARNS JENNIFER C & WILLIAM H BARNS JTS

Located at

15 LONGFELLOW ST

PERMIT ID: 2017-00308

ISSUE DATE: 04/14/2017

CBL: 126 B015001

has permission to Legalization of one (1) nonconforming dwelling unit to legalize use as a three- (3-)

family.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ David Petruccelli

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

three family

Building Inspections

Type: 5B

Use Group: R-2

Residential Apartments (3 Units)

Nonsprinkled

ENTIRE

Municipal Housing Code

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Legalize Nonconforming units
Legalize Nonconforming units
Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 03/09/2017 2017-00308 126 B015001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Three Family Legalization of one (1) nonconforming dwelling unit to legalize use as a three- (3-) family. Reviewer: Ann Machado **Dept:** Zoning **Status:** Approved w/Conditions **Approval Date:** 04/13/2017

Conditions:

Note:

1) With the issuance of this permit and the certificate of occupancy this property shall remain a three family dwelling. Any change of use shall require a separate permit application for review and approval.

Ok to Issue:

2) This permit is being approved on the condition that the applicant completes all required work to bring the property into compliance with the applicable housing and life safety codes. A Certificate of Occupancy for the legalized unit shall not be issued until such work is completed, as verified by a final inspection. If a Certificate of Occupancy is not issued, the approval of the legalized unit is void and the applicant shall be required to remove the unit.

Dept: Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Jeanie Bourke **Approval Date:** 04/06/2017 **Note:** Ok to Issue: ✓

Conditions:

- 1) Egress size windows are required (1) in each sleeping room per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings.
- 2) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level.
 - The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection.
- 3) This permit recognizes a pre-existing land use and does not require or certify compliance with the City's current building code. The inspection performed will be done pursuant to the City's Minimum Standards for Housing, The Housing Code. All violations shall be corrected prior to the final inspection and the issuance of the Certificate of Occupancy.
- 4) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.
- 5) This is a Change of Use ONLY permit. It does NOT authorize any construction activities.
- 6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** David Petruccelli **Approval Date:** 04/03/2017 **Note:** • Ok to Issue: ✓

Conditions:

- 1) Sixty minute self closing fire doors required to common stair ways.
- 2) Shall meet NFPA 101(2009) Ch. 30 Existing Apartment Buildings
- 3) Single-station Carbon Monoxide (CO) alarms powered by the building's electrical service with battery backup are required within the dwelling units. CO alarms shall be installed in the following locations:
 - (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms
 - (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces New CO alarms shall be hardwired.

- 4) Hardwired single-station smoke alarms are required within the dwelling units. Smoke alarms shall be installed in the following locations:
 - (1) All sleeping rooms
 - (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms
 - (3) On each level of the dwelling unit, including basements.

New smoke alarms shall be photoelectric powered by the building's electrical service with battery backup.

5) Building shall comply with City Code Chapter 10 prior to certificate of occupancy.