Portland Maine Yes. Google's good here.

Ann Machado <amachado@portlandr

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/13/17

15 Longfellow St. - Permit 2017-00308 - legalization permit

David Petruccelli <petruccellid@portlandmaine.gov> Mon, Apr 10, 2017 at 10:29 AM
To: Ann Machado <amachado@portlandmaine.gov>
Cc: Chuck Fagone <psf@portlandmaine.gov>

Ann,

She needed to install 1 fire door for the first floor unit, side entrance. And to remove some no longer required smoke alarms, because of the new hard-wired ones she installed.

David

Capt. David Petruccelli
Portland Fire Department
Fire Prevention &
Community Outreach Branch
380 Congress St
Portland, ME 04101

Office: 207-874-8400
Mobile: 207-400-7488
Fax: 208-874-8410
[Quoted text hidden]