Ben Walter

From: Jerry Bosse <JBosse@htfp.me>
Sent: Friday, April 26, 2013 7:43 AM
To: Ben Walter
Subject: RE: 509 Forest Ave - HopeGateway

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/21/13

Hello Ben,
I have reviewed the drawings and based on "NFPA 13, 2010, A.5.2" this use will be a "light hazard" usage which will meet the fire protection the existing sprinkler system provides. However I do suggest an inspection of the space to verify proper coverage throughout.

From: Ben Walter [mailto:bwalter@cwsarch.com]
Sent: Wednesday, April 24, 2013 12:50 PM
To: Jerry Bosse
Subject: 509 Forest Ave - HopeGateway

Hi Jerry,

Attached are the proposed plans. Note I have listed the SF of the proposed internal uses in a table on the bottom.

Please provide me with a statement as to whether any modifications to the sprinkler or fire alarm system would be required for this change of use.

Thanks for your help.

Ben

Ben Walter AIA, President
CWS Architects | Portland, Maine
Maine Licensed Architect
www.cwsarch.com
T: 207-774-4441
F: 207-774-4016
C: 207-232-3348
bwalter@cwsarch.com