

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ALPINE REALTY CORP /n/a

Located at

509 FOREST AVE

PERMIT ID: 2013-00931

ISSUE DATE: 06/24/2013

CBL: 127 A002001

has permission to **Change of use from Retail to Religious Assembly with no alterations** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Benjamin Wallace Jr

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

With permit #2013-00930 allow #509 section of the building to be a place of religious assembly

Building Inspections

Use Group: A-3 (B, M) **Type:** 2B
Assembly - Place of Worship
w/Accessory Classrooms
Floor 1, Left Side Front
MUBEC/IBC 2009

Fire Department

Classification:
Assembly (Mixed Use building)
First floor front left
NFPA 2009

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Electrical Close-in

Certificate of Occupancy/Final

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-00931	Date Applied For: 05/08/2013	CBL: 127 A002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Religious Assembly	Proposed Project Description: Change of use from Retail to Religious Assembly with no alteration			
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 05/09/2013	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This property at #509 Forest Avenue shall remain as a religious place of assembly. Any change of use shall require a separate permit application for review and approval.				
2) Separate permits shall be required for any new signage.				
<hr/>				
Dept: Building	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 06/21/2013	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) <input type="checkbox"/> Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) <input type="checkbox"/> This is a Change of Use ONLY permit with minor construction to add a fire rated door to the exit access and some windows to the existing classroom walls or doors.				
3) <input type="checkbox"/> Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Benjamin Wallace Jr	Approval Date: 06/21/2013	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) **The fire alarm system design shall be evaluated for the renovated areas by an NICET IV certified interior fire alarm designer or a licensed engineer for compliance with the code. A compliance letter is required prior to the final inspection.** **A current inspection sticker from an approved fire alarm inspection company is required prior to the final inspection.**				
2) Application requires State Fire Marshal approval.				
3) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information.				
4) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.				
5) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
6) Fire extinguishers are required per NFPA 1.				
7) All means of egress to remain accessible at all times.				
8) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
9) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
10) Construction or installation shall comply with City Code Chapter 10.				

- 11 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 12 The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition.
- 13 The approved plans with the Building Department Approved stamp shall be maintained on site for inspection.
- 14 The maximum occupant load shall be posted at the main exit from the sanctuary with an approved legible sign.
- 15 Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 16 Fire walls, fire barriers, fire partitions, smoke barriers and smoke partitions or any other wall required to have protected openings or penetrations shall be effectively and permanently identified with signs or stenciling in accessible concealed floor, floor-ceiling or attic spaces at intervals not exceeding 30 feet with lettering not less than 0.5 inches in height.