

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

BLOY SARAH G

**Located at**

290 BAXTER BLVD (BLDG G)

**PERMIT ID:** 2017-00202

**ISSUE DATE:** 04/19/2017

**CBL:** 127 A003054

has permission to **Removing structural wall and install LVL beam. New bathroom fixtures & kitchen updates In unit G3.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Jason Grant*

*/s/ Brian Stephens*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Residential condominium in building (bldg. 4) with 18 residential condominiums

***Building Inspections***

**Use Group:** R-2      **Type:** 3B  
Residential Apartment (condominium)  
3rd Floor  
MUBEC/IBC-2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Commercial

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-00202	<b>Date Applied For:</b> 02/24/2017	<b>CBL:</b> 127 A003054
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: Residential condo in building with 18 residential condominiums		<b>Proposed Project Description:</b> Removing structural wall and install LVL beam. New bathroom fixtures & kitchen updates In unit G3.		
<b>Dept:</b> Zoning		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Ann Machado	<b>Approval Date:</b> 02/27/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>				
1) This property shall remain a residential condominium in a multiresidential condominium building. Any change of use shall require a separate permit application for review and approval.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
<b>Dept:</b> Building Inspecti		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Brian Stephens	<b>Approval Date:</b> 04/18/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>				
1) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4				
2) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection.				
3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) Beams shall be supported by posts and solid blocking to carry the load path to another beam, foundation or footing.				
5) All existing fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall be maintain for rating and continuity. Additional materials may need to be added for compliance.				
6) The design load spec sheets for any engineered beam(s) / Trusses must be submitted to this office prior to the installation of said components.				
7) Egress size windows are required (1) in each sleeping room per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings.				
8) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7				
9) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
<b>Dept:</b> Fire		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jason Grant	<b>Approval Date:</b> 04/18/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>				
1) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas 2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.				

- 2) City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be non-ionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
1. Inside all sleeping rooms.
  2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
  3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 3) All construction shall comply with City Code, Chapter 10.  
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43  
All construction shall comply with 2009 NFPA 1, Fire Code.  
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).  
All means of egress to remain accessible at all times.