

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 03-1155	Issue Date:	CBL: 127 A004001
-----------------------	-------------	---------------------

Location of Construction: 45 Dartmouth St	Owner Name: 49 Dartmouth Llc	Owner Address: 715 Boylston St	Phone: 617-266-4040
Business Name: n/a	Contractor Name: Portland Airconditioning, Inc.	Contractor Address: 205 Lincoln St. S. Portland	Phone: 2077674567
Lessee/Buyer's Name n/a	Phone: n/	Permit Type: HVAC	Zone: B2b

Past Use: Commercial	Proposed Use: Commercial / Install Natural gas from ^{HWAC} the roof. 07	Permit Fee: \$138.00	Cost of Work: \$12,980.00	CEO District: 3
Proposed Project Description: Install Natural Gas from ^{HWAC} the roof.		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: <i>NA</i> Type: <i>11/14/03</i> <i>August</i>	
		Signature: <i>guy</i>	Signature: <i>August</i>	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)				
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied				
Signature: _____ Date: _____				

Permit Taken By: gg	Date Applied For: 09/15/2003	Zoning Approval
------------------------	---------------------------------	------------------------

<ol style="list-style-type: none"> This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. Building permits do not include plumbing, septic or electrical work. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.. 	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>9/23/03</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>[Signature]</i>
---	--	---	---

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 03-1155	Date Applied For: 09/15/2003	CBL: 127 A004001
-----------------------	---------------------------------	---------------------

Location of Construction: 45 Dartmouth St	Owner Name: 49 Dartmouth Llc	Owner Address: 715 Boylston St	Phone: 617-266-4040
Business Name: n/a	Contractor Name: Portland Airconditioning, Inc.	Contractor Address: 205 Lincoln St. S. Portland	Phone: (207) 767-4567
Lessee/Buyer's Name n/a	Phone: n/	Permit Type: HVAC	

Proposed Use: Commercial / Install Natural gas HVAC on the roof.	Proposed Project Description: Install Natural Gas HVAC on the roof.
---	--

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 09/23/2003
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
Dept: Building	Status: Approved with Conditions	Reviewer: Mike Nugent	Approval Date: 11/14/2003
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Must modify the structure consistent with the Engineer's letter dated 10/17/2003			
Dept: Fire	Status: Approved with Conditions	Reviewer: Lt. MacDougal	Approval Date: 09/24/2003
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) the gas installation shall be in complainece with NFPA 58 (National Gas Code)			

Comments:
9/24/2003-kwd: no roof structural information provided; applicant provided interior floorplans only. Applicant called 9/24/03. Got it!!!!!!!!!!!!!!!!!!!!!!!!!!!!mjn
9/30/2003-kwd: 9/29/2003:NEED structural plans, HVAC unit details provided,

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 03-1155	Date Applied For: 09/15/2003	CBL: 127 A004001
------------------------------	--	----------------------------

Location of Construction: 45 Dartmouth St	Owner Name: 49 Dartmouth Llc	Owner Address: 715 Boylston St	Phone: 617-266-4040
Business Name: n/a	Contractor Name: Portland Airconditioning, Inc.	Contractor Address: 205 Lincoln St. S. Portland	Phone: (207) 767-4567
Lessee/Buyer's Name: n/a	Phone: n/	Permit Type: HVAC	

Proposed Use: Commercial / Install Natural gas HVAC on the roof.	Proposed Project Description: Install Natural Gas HVAC on the roof.
--	---

Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 09/23/2003
Note: **Ok to Issue:**

Dept: Building **Status:** Pending **Reviewer:** Mike Nugent **Approval Date:** **Ok to Issue:**

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Lt. MacDougal **Approval Date:** 09/24/2003
Note: **Ok to Issue:**

1) the gas installation shall be in compliance with NFPA 58 (National Gas Code)

Comments:


09/24/2003-kwd: no roof structural information provided; applicant provided interior floorplans only. Applicant called 9/24/03.

09/30/2003-kwd: 9/29/2003:NEED structural plans, HVAC unit details provided,



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



127 A004

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 49 Dartmouth St Use of Building _____ Date 09/15/03
 Name and address of owner of appliance Boston Gould 715 Boylston St
Boston, MA 02116 (617) 266-4040
 Installer's name and address Portland Air Conditioning Inc
205 Lincoln St. SE Portland, ME Telephone 207.707.4567

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: Boiler

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PNT434
- Other _____

Type of Chimney:

- Masonry Lined
Factory built u/a
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas - natural


Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 12,980

Permit Fee: \$ 138.00



Approved

Fire: et my
 Ele.: _____
 Bldg.: _____

Approved with Conditions


See attached letter or requirement

Inspector's Signature _____

Date Approved 09/15/03

Signature of Installer _____

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy



P.O. BOX 10300 PORTLAND, MAINE 04104 TEL (207) 767- 4567 FAX (207) 767 4566

FAX TRANSMITTAL.....

DATE 10/21/03

SUBJECT 49 Dartmouth

TO Mike ATTN _____


FROM Reihy PAGES TO FOLLOW _____

MESSAGE Letter From Engineer as requested

REPLY _____

DESIGN/BUILD SHEET METAL FABRICATION AND INSTALLATION SYSTEMS MAINTENANCE

RECEIVED OCT 21



October 17, 2003

Kathryn Mooney
Portland Air Conditioning
205 Lincoln St
S. Portland, ME 04106

RE: ROOFTOP INSTALLATION AT 49 DANFORTH STREET, PORTLAND, ME

Dear Kathy:


We have reviewed the framing relative to the additional weight proposed with the installation of the rooftop mechanical unit at 49 Danforth Street. On Monday, October 13, we met on site to review the actual proposed location for the unit. The proposed unit is a Bryant Model 580F090, having a total unit weight of 978 pounds with economizer.

We have reviewed the existing framing and capacities relative to the 1999 BOCA building code and offer the following recommendations relative to the installation of the support rails as proposed:

1. Provide on rail directly above the existing W12 steel beam. Provide continuous 2x blocking between the top of the steel beam and the underside of the wood plank decking for the length of the rail.
2. Install the second rail such that it spans over two of the existing timber roof purlins that extend between the exterior wall on the Danforth Street side of the building and the W12 steel beam.
3. Provide a two (2) full length 2x10, Douglas Fir, No. 2 or better, rafters sections sistered one on each side of the existing purlins. Fasten the 2 x 10s to the purlins using 3 rows of 12d nails at 8 inches on-center spacing. No modification is required at either end bearing condition.

Should you have additional questions or concerns, please feel free to contact me.

Best regards,
allied engineering, inc.



William P. Faucher, P.E.
Principal

M:\PROJECTS\2003\49 Danforth - Portland Air\Mooney reinforcement letter - 49 Danforth.doc

One Westbrook Common, Westbrook, ME 04092
207-854-8126 Voice 207-854-0603 Fax

Web: www.allied-eng.com
E-Mail: info@allied-eng.com

PHYSICAL DATA 580F090-150


UNIT SIZE 580F	090	102	120	150
NOMINAL CAPACITY (tons)	7 1/2	8 1/2	10	12 1/2
OPERATING WEIGHT (lb)				
Unit				
AI/AI*	870	880	1035	1050
AI/Cu*	881	896	1057	1077
Cu/Cu*	893	907	1080	1100
Economizer				
Durablade	44	44	44	44
EconoMiser	62	62	62	62
Roof Curb†	143	143	143	143
COMPRESSOR				
Quantity	2	2	2	2
No. Cylinders (per Circuit)	2	2	2	—
Oil (oz)	42 ea	85 ea	54 ea	54 ea
REFRIGERANT TYPE				
Expansion Device	Fixed Orifice Metering Device			
Operating Charge (lb-oz)				
Circuit 1	4-13	6-14	7- 3	8-10
Circuit 2	4-14	9- 2	7-13	8- 6
CONDENSER COIL				
Rows...Fins/in.	1...17	2...17	2...17	2...17
Total Face Area (sq ft)	20.50	18.00	20.47	25.00
CONDENSER FAN				
Nominal Cfm	6400	6400	7000	7000
Quantity...Diameter (in.)	2...22	2...22	2...22	2...22
Motor Hp...Rpm	1/4...1100	1/4...1100	1/4...1100	1/4...1100
Watts Input (Total)	600	600	600	600
EVAPORATOR COIL				
Rows...Fins/in.	3...15	3...15	3...15	4...15
Total Face Area (sq ft)	8.0	8.0	10.0	11.1
EVAPORATOR FAN				
Quantity...Size (in.)	Std 1...15 x 15	Std 1...15 x 15	Std 1...15 x 15	Std 1...15 x 15
	Alt 1...15 x 15	Alt 1...15 x 15	Alt 1...15 x 15	Alt 1...15 x 15
Type Drive	High-Static	High-Static	High-Static	High-Static
	Std Belt	Std Belt	Std Belt	Std Belt
	Alt Belt	Alt Belt	Alt Belt	Alt Belt
	High-Static	High-Static	High-Static	High-Static
Nominal Cfm	3000	3100	4000	5000
Maximum Continuous Bhp	Std 2.40	Std 2.40	Std 2.40	Std 3.70
	Alt 2.40	Alt —	Alt 2.90	Alt 5.25
	High-Static	High-Static	High-Static	High-Static
Motor Frame Size	Std 56	Std 56	Std 56	Std 56
	Alt 56	Alt —	Alt 56	Alt 56
	High-Static	High-Static	High-Static	High-Static
Nominal Rpm High/Low	Std —	Std —	Std —	Std —
	Alt —	Alt —	Alt —	Alt —
	High-Static	High-Static	High-Static	High-Static
Fan Rpm Range	Std 1725	Std 1725	Std 1725	Std 1725
	Alt 590-840	Alt 685-935	Alt 685-935	Alt 860-1080
	High-Static	High-Static	High-Static	High-Static
	Std 685-935	Std —	Std 835-1085	Std 900-1260
	Alt 860-1080	Alt 860-1080	Alt 830-1130	Alt —
	High-Static	High-Static	High-Static	High-Static
Motor Bearing Type	Ball	Ball	Ball	Ball
Maximum Allowable Rpm	2100	2100	2100	2100
Motor Pulley Pitch Diameter Min/Max (in.)	Std 2.4/3.4	Std 2.8/3.8	Std 2.8/3.8	Std 4.0/5.0
	Alt 2.8/3.8	Alt —	Alt 3.4/4.4	Alt 3.1/4.1
	High-Static	High-Static	High-Static	High-Static
Nominal Motor Shaft Diameter (in.)	Std 5/8	Std 5/8	Std 5/8	Std 7/8
	Alt 1/2	Alt —	Alt 7/8	Alt 7/8
	High-Static	High-Static	High-Static	High-Static
Fan Pulley Pitch Diameter (in.)	Std 7.0	Std 7.0	Std 7.0	Std 8.0
	Alt 7.0	Alt —	Alt 7.0	Alt 5.9
	High-Static	High-Static	High-Static	High-Static
Belt, Quantity...Type...Length (in.)	Std 1...A...49	Std 1...A...49	Std 1...A...49	Std 1...A...52
	Alt 1...A...49	Alt —	Alt 1...A...49	Alt 1...BX...46
	High-Static	High-Static	High-Static	High-Static
Pulley Center Line Distance (in.)	Std 16.75-19.25	Std 16.75-19.25	Std 15.85-17.50	Std 15.85-17.50
	Alt 16.75-19.25	Alt —	Alt 15.85-17.50	Alt 15.85-17.50
	High-Static	High-Static	High-Static	High-Static
Speed Change per Full Turn of Movable Pulley Flange (rpm)	Std 50	Std 50	Std 50	Std 44
	Alt 50	Alt —	Alt 50	Alt 50
	High-Static	High-Static	High-Static	High-Static
Movable Pulley Maximum Full Turns From Closed Position	Std 5	Std 5	Std 5	Std 5
	Alt 5	Alt —	Alt 5	Alt 6
	High-Static	High-Static	High-Static	High-Static
Factory Setting	Std 5	Std 5	Std 6	Std 5
	Alt 5	Alt —	Alt 5	Alt 5
	High-Static	High-Static	High-Static	High-Static
Factory Speed Setting (rpm)	Std 590	Std 685	Std 685	Std 860
	Alt 685	Alt —	Alt 835	Alt 960
	High-Static	High-Static	High-Static	High-Static
Fan Shaft Diameter at Pulley (in.)	Std 860	Std 860	Std 887	Std —
	Alt 1	Alt 1	Alt 1	Alt 1
	High-Static	High-Static	High-Static	High-Static

LEGEND
 AI — Aluminum
 Bhp — Brake Horsepower
 Cu — Copper

*Evaporator coil fin material/condenser coil fin material. Contact your local representative for details about coated fins.
 †Weight of 14-in. roof curb.
 **Rollout switch lockout is manually reset by interrupting power to unit or resetting thermostat.

NOTE: High-static motor not available on size 150 units.

bryant



580F036-072

Standard-Efficiency Rooftop Units with:

- Exclusive integrated gas control board with diagnostics
- Alumagard™ heat exchanger coating
- Induced-draft fan for gas combustion
- Tubular, dimpled heat exchangers
- Pre-painted galvanized steel cabinet for long life and quality appearance
- Commercial strength base rails with built-in rigging capability
- Convertible design for vertical or horizontal supply/return
- Non-corrosive, sloped condensate drain pan, meets ASHRAE 62 (IAQ)
- Two-inch return-air filters (IAQ)
- A wide assortment of factory-installed options available, including high static drives that provide additional performance range
- High and low (loss-of-charge) pressure switches and freeze-stat
- Refrigerant filter drier

FEATURES/BENEFITS

Every compact one-piece unit arrives fully assembled, charged, tested, and ready to run.

INTEGRATED GAS CONTROLLER (IGC) — All ignition components are contained in the compact IGC which is easily accessible for servicing. The IGC control board provides built-in diagnostic capability. An LED (light-emitting diode) simplifies troubleshooting by providing visual fault notification and system status confirmation.

The IGC also contains an exclusive anti-cycle protection for gas heat operation. After 4 continuous cycles on the unit high-temperature limit switch, the gas heat operation is disabled, and an error code is issued. This feature greatly improves reliability of the rooftop unit.

The IGC also contains burner control logic for accurate and dependable gas ignition. The LED is visible without removing the unit control box access panel. This LED fault-notification system reduces service person troubleshooting time and minimizes service costs. The IGC also maximizes heating efficiency by controlling indoor-fan on and off delays.

QUIET, EFFICIENT OPERATION AND DEPENDABLE PERFORMANCE — Compressors have vibration isolators for quiet operation. Efficient fan and motor design permits operation at low sound levels and all 580F units are mounted either on

mounting plate (090-150).

The 580F090-150 units offer load operation using 2 stages of

Quiet and efficient operation is provided by drive evaporator fans on sizes 036-060. The evaporator fans (on all units). The belt-driven fans are equipped with variable-pitch pulleys which permit within the rpm ranges of the factory-supplied

Increased operating efficiency is achieved through designed coils featuring staggered internally enhanced tubes. Fins are ripple-edged for strength, lanced, and dovetailed for higher heat transfer.

Tubular, dimpled gas heat exchangers optimize heat transfer for improved efficiency. The tubular design permits hot gases to make multiple passes across the path of the supply air. The dimpled design creates a turbulent gas flow to maximize heating efficiency.

The California Air Quality Management Districts NO_x requirement of 40 nanograms/joule or less is met on 036-060 size Low NO_x models.

The extra thick Alumagard™ heat exchanger coating provides corrosion resistance and ensures long life. Low NO_x models have 409 stainless steel firing tubes.

The unsightly appearance of flue stacks is eliminated and the effects of wind on heating operations are diminished by the induced draft combustion system. The inducer fan draws hot combustion gas through the heat exchanger at the optimum rate for the most effective heat transfer. The heat exchanger operates under negative pressure, preventing flue gas leakage into the indoor supply air.

During the Heating mode, the evaporator-fan relay automatically starts the evaporator fan after the heat exchanger warms up to a suitable temperature. The 30-second fan delay prevents cold air from entering the supply duct system when the conditioned space is calling for heat to maximize efficiency and comfort.

The direct-spark ignition system saves operating expense when compared to pilot ignition systems. No crossover tube is required, therefore no sooting or pilot fouling problems can occur.

All 580F standard units are designed for natural gas, but an accessory LP (liquid propane) conversion kit is available.

UNIT SIZE 580F
FURNACE SECTION
Return Switch Circuit
Burner (F)
(in...drill size)
Natural Gas
Liquid Propane
Thermostat Heat Antic
Setting (emps)
200, 230 v and 575
480 v
Gas Input (Btu
Efficiency (Btu
Size) (F
Temper
Manuf
G

BASE UNIT DIMENSIONS — 580F090-150

UNIT	STANDARD UNIT WEIGHT		DURABLADE ECONOMIZER WEIGHT		ECONOMIZER WEIGHT		CORNER WEIGHT (A)		CORNER WEIGHT (B)		CORNER WEIGHT (C)		CORNER WEIGHT (D)		"H"		"J"		"K"		"L"	
	Lb	Kg	Lb	Kg	Lb	Kg	Lb	Kg	Lb	Kg	Lb	Kg	Lb	Kg	ft-in.	[mm]	ft-in.	[mm]	ft-in.	[mm]	ft-in.	[mm]
580F090	870	395	44	20	62	28	189	86	161	73	239	109	280	127	1-2 ⁷ / ₈	[378]	3-5 ⁵ / ₁₆	[11050]	2-9 ¹¹ / ₁₆	[858]	2-2 ⁷ / ₁₆	[872]
580F102	880	399	44	20	62	28	191	87	163	74	242	110	284	129	3-3 ⁷ / ₈	[1013]	3-5 ⁵ / ₁₆	[11050]	2-9 ¹¹ / ₁₆	[858]	2-2 ⁷ / ₁₆	[872]
580F120	1035	469	44	20	62	28	225	102	192	87	285	129	333	151	2-5 ⁷ / ₈	[759]	4-1 ⁵ / ₁₆	[1253]	3-0 ³ / ₈	[924]	2-10 ⁷ / ₁₆	[875]
580F150	1050	476	44	20	62	28	228	103	195	88	289	131	338	153	1-2 ⁷ / ₈	[378]	4-1 ⁵ / ₁₆	[1253]	3-0 ³ / ₈	[924]	2-10 ⁷ / ₁₆	[875]







CONNECTION SIZES	
A	1 ³ / ₈ " Dia [36] Field Power Supply Hole
B	2 ¹ / ₂ " Dia [64] Power Supply Knockout
C	1 ³ / ₄ " Dia [44] Charging Port Hole
D	7 ¹ / ₈ " Dia [22] Field Control Wiring Hole
E	3 ¹ / ₄ "-14 NPT Condensate Drain
F	1 ¹ / ₂ "-14 NPT Gas Connection 125 MBH, Input Units 3 ¹ / ₄ "-14 NPT Gas Connection 180 MBH, 224 MBH, and 250 MBH Input Units
G	2" Dia [51] Power Supply Knockout

BOTTOM POWER CHART, THESE HOLES REQUIRED FOR USE WITH ACCESSORY PACKAGES —
 CRBTMPWR001A00, 3A00 (1¹/₂", 3¹/₄")
 OR CRBTMPWR002A00, 4A00 (1¹/₂", 1¹/₄")

THREADED CONDUIT SIZE	WIRE USE	REQUIRED HOLE SIZES (MAX.)
1 ¹ / ₂ "	24 V	1 ¹ / ₈ " [22.2]
3 ¹ / ₄ "	Power*	1 ¹ / ₈ " [28.4]
1 ¹ / ₄ "	Power*	1 ³ / ₄ " [44.4]
(003) 1 ¹ / ₂ " FPT	Gas	1 ¹ / ₄ " [31.8]
(004) 3 ¹ / ₄ " FPT	Gas	1 ⁵ / ₈ " [41.3]


*Select either 3¹/₄" or 1¹/₄" for power, depending on wire size.


- NOTES:**
- Dimensions in [] are in millimeters.
 - Center of gravity.
 - Direction of airflow.
 - On vertical discharge units, ductwork to be attached to accessory roof curb only. For horizontal discharge units field-supplied flanges should be attached to horizontal discharge openings, and all ductwork should be attached to the flanges.
 - Minimum clearance (local codes or jurisdiction may prevail):
 - Between unit (flue side) and combustible surfaces, 48 inches.
 - Bottom of unit to combustible surfaces (when not using curb) 1 inch. Bottom of base rail to combustible surfaces (when not using curb) 0 inches.
 - Condenser coil, for proper airflow, 36 in. one side, 12 in. the other. The side getting the greater clearance is optional.
 - Overhead, 60 in. to assure proper condenser fan operation.
 - Between units, control box side, 42 in. per NEC (National Electrical Code).
 - Between unit and ungrounded surfaces, control box side, 36 in. per NEC.
 - Between unit and block or concrete walls and other grounded surfaces, control box side, 42 in. per NEC.
 - Horizontal supply and return and, 0 inches.
 - With the exception of the clearance for the condenser coil and combustion side as stated in Notes 5a, b, and c, a removable fence or barricade requires no clearance.
 - Units may be installed on combustible floors made from wood or Class A, B, or C roof covering material if set on base rail.
 - The vertical center of gravity is 1'-7" [483] for 090 and 102, 1'-11" [584] for 120 and 150 up from the bottom of the base rail.




Handwritten note: This ends over beam


49 Dartmouth Rooftop Unit Installation





	
<p>FNC CADD Engineering Resource Center</p> <p>15 Parker St. Providence, Rhode Island 02903 401-476-4511 Fax 401-476-4512 E-Mail: info@fncadd.com</p>	
PROJECT: _____ DRAWN: _____ DATE: _____	SHEET NO: _____ OF _____




GROUND FLOOR PLAN
 SCALE: 1/4" = 1'-0"

49 Dartmouth



11 Snow St.
 Portland, Maine 04101
 207-478-8711 Fax 207-626-2515
 E-Mail: mya@fmcadd.com

DATE: 10/28/08	BY: J.M.	CHECKED: J.M.	SCALE: 1/4" = 1'-0"	PROJECT: 49 DARTMOUTH	SHEET: 12
----------------	----------	---------------	---------------------	-----------------------	-----------



CITY OF PORTLAND, MAINE

Department of Building Inspections

Sept 18 2003

Received from Porter Construction

Location of Work 49 Jackson Ave

Cost of Construction \$ _____

Permit Fee \$ 138.00

Building (I1) Plumbing (I5) _____ Electrical (I2) _____ Site Plan (U2) _____

Other Lead

CBL: 197 A 004

Check #: 11803

Total Collected \$ 138.00

THIS IS NOT A PERMIT

No work is to be started until PERMIT CARD is actually posted upon the premises. Acceptance of fee is no guarantee that permit will be granted. PRESERVE THIS RECEIPT. In case permit cannot be granted the amount of the fee will be refunded upon return of the receipt less \$10.00 or 10% whichever is greater.

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Permit Copy

[Handwritten signature]