



KEYED NOTES:

- ① EXISTING EQUIPMENT BEING DISCONNECTED AS SHOWN ON ED101 IS TO BE RELOCATED TO THIS LOCATION. ALL EXISTING CIRCUITING, SPECIAL RECEPTACLES, COND COPS AND DATA DROPS ASSOCIATED WITH THE RELOCATED EXISTING EQUIPMENT ARE TO BE REUSED AT THIS LOCATION. PROVIDE POWER POLES AS REQUIRED. REFER TO DROP MATRIX.
- ② EXISTING DISCONNECT. FEEDS PANEL DP1.
- ③ EXISTING DISCONNECT. FEEDS PANEL LP3.
- ④ EXISTING DISCONNECT. FEEDS BOTH 200A DISCONNECTS.
- ⑤ EXISTING DISCONNECT. FEEDS PANEL P2.
- ⑥ RELOCATE THIS EXISTING CIRCUIT AND TWIST LOCK RECEPTACLE REFER TO KEY NOTE 7. LEAVE CONDUIT AND OUTLET BOX IN PLACE AND CONVERT INTO 120V RECEPTACLE.
- ⑦ RELOCATE EXISTING CIRCUIT AND TWIST LOCK RECEPTACLE TO THIS LOCATION. NOTE PANEL AND CIRCUIT NUMBER ON RECORD DRAWINGS. REFER TO KEY NOTE 6. MOUNTING HEIGHT TO BE 42" TO CENTER.

NOTE:

- 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

A1 FIRST FLOOR PLAN

1/8"=1'-0"

<p>SHEET TITLE: FIRST FLOOR POWER PLAN</p> <p>SHEET No. EP101</p>	<p>UNIVERSITY OF SOUTHERN MAINE RENOVATION 501 FOREST AVENUE PORTLAND, MAINE</p> <p>ISSUED FOR DESIGN DEVELOPMENT 4-12-10</p> <p>CURRENT ISSUE STATUS:</p>	<p>PROJECT NORTH</p>	<p>ARCHITECTURE ENGINEERING PLANNING INTERIOR DESIGN COMMISSIONING</p> <p>SMRT</p> <p>144 Fore Street/P.O. Box 618 Portland, Maine 04104 tel. (207) 772-3846 fax. (207) 772-1070 www.smrting.com</p>
<p>SCALE: 1/8"=1'-0"</p> <p>PROJECT MANAGER: SLB</p> <p>IC/DRAWN BY: CDS</p> <p>A/E OF RECORD: DJT</p> <p>CAD FILE: EP101-091748</p> <p>PROJECT NO: 091748</p> <p>DATE:</p>	<p>GRAPHIC SCALE:</p> <p>0 1'</p>	<p>REV</p> <p>DESCRIPTION</p> <p>DATE</p>	<p>SCALE: 1/8"=1'-0"</p> <p>PROJECT MANAGER: SLB</p> <p>IC/DRAWN BY: CDS</p> <p>A/E OF RECORD: DJT</p> <p>CAD FILE: EP101-091748</p> <p>PROJECT NO: 091748</p> <p>DATE:</p>