APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Permit No. [illegible]

Portland, Maine, September 22, 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter remove the following building structure, equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

40-46

Location Chamery Street
Lots 38 and 39 and 35 Within Fire Limits? No Dist. No.

Owner's or lessee's name and address Dr. David Miller, 28 Sawyer Street Telephone

Contractor's name and address J. R. Low, 102 Allen Avenue Telephone, 2-8272

Architect Plans filed yes No. of sheets 1

Proposed use of building Dwelling House with one car garage attached No. families 1

Other buildings on same lot

Estimated cost $ 7,000. Fee $ 4.00

Description of Present Building to be Altered

Memorandum from Department of Building Inspection, Portland, Maine

40-46 Chamery St.---New Dwelling and Garage for Dr. David Miller by J. R. Low, Builder
9/24/41

To Owner and Builder:

Please pay particular attention to the specifications on your copy of the application as to fire door between house and garage. If you want a door with panels you will have to go to the labelled door mentioned.

The fact that a stairway is indicated to the third floor indicates that there will eventually be some kind of floor there although the application says "ceiling only". The third floor joists, therefore, should be no more than 16 inches from center to center, and I recommend 16 inches from center to center against the day it may be desired to provide some type of living quarters up there with or without dormers.

CC Dr. David Miller, 28 Sawyer St.

(*Signed*) Warren McDonald
Inspector of Buildings

the heating contractor,

Details of New Work

Is any plumbing work involved in this work? Yes

Is any electrical work involved in this work? Yes Height average grade to top of plate 10

Size, front 45'-8" depth 25'6" No. stories 2 Height average grade to highest point of roof 24

To be erected on solid or filled land? solid 8" to trench wall under garage earth or rock? earth

Material of foundation concrete Thickness, top 12" bottom 12" cellar yes

Material of underpinning brick Height 16" Thickness 12

Kind of roof pitch Rise per foot 3 9" Roof covering asphalt roofing Class C Underwriters

No. of chimneys 4 Material of chimneys brick Lining tile

Kind of heat hot air Type of fuel oil Is gas fitting involved?

Framing lumber—Kind fir and hemlock Dressed or full size? dressed

Corner posts 4x6 Sills 4x6 Girt or ledger board? girt Size 2x14

Material columns under girders Lally columns reinforced Size 3" Max. on centers 7'

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2x10, 2nd 2x10, 3rd 2x8 ceiling, roof 2x8 (corner stairway only)

On centers: 1st floor 16", 2nd 16", 3rd 20", roof 20"

Maximum span: 1st floor 13' 2nd 14' 3rd 14', roof

If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot None to be accommodated 1

Total number commercial cars to be accommodated None

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner By Dr. David Miller J. Everett Low

INSPECTION COPY