DWG 2

1/2" = 1-0"

75 BAY VIEW DRIVE

DECK FRAMING PLAN

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: _____

P.T. 2x6 SILL PLATE OVER 2' REINFORCED CEMENT BLOCK WALL

NOTE: DECK WILL BE AT GRADE OR <6" ABOVE GRADE

10' SPAN

2x8-12" O.C. STRINGERS (TYP)

TOP FLANGE JOIST HANGER ATTACHED TO SILL PLATE BOLT-ANCHORED TO FILLED BLOCK WALL

TYP BOLT TO SILL PLATE

2x6 CEDAR DECKING OVER STRINGERS

JOIST HANGER (TYP)

DOUBLED 2x8

3'-0" O.C.

10'-9"

HOT TUB

POSTS FOR PERGOLA

7'-0" O.C.

5'-0"

SISTERED

6'-0"

HOUSE

18'