BRUCE
RONAYNE
HAMILTON
ARCHITECTS

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/12/14

Building and Life Safety Code Review
Alterations to:
Rite Aid Store #4133
701 Forest Avenue
Portland, Maine

Date: January 8, 2014, by Randy Kangas, Associate
Project # 13-131

Jurisdiction:
City of Portland, Maine

Applicable Code(s) including but not limited to the following:
MUBEC – State of Maine Building Code
2009 International Existing Building Code
2009 International Building Code
NFPA Life Safety 101, 2007
City of Portland Code, Chapter 10, Fire Prevention and Protection

Building Code Review:

Project Description:
Alterations to an existing Mercantile Occupancy

Type of Construction: 2B per IBC 602.2

Use and Occupancy Classification:
Use 'M' Mercantile per IBC 309.1. and NFPA Life Safety Code Section 37.1

Gross Areas
First Floor Building Gross floor area = 12,035 S.F. Gross Floor Area.
First Floor Work Area for alterations = 427 S.F. (See plans)
Ratio of Total Building floor area (12,035 S.F.) to Total Work Area (427 S.F.) = 3.5%

NOTE: THE RITE AID TENANT SPACE IS PROTECTED THROUGHOUT BY AN AUTOMATIC SPRINKLER SYSTEM AND HAS A MONITORED FIRE ALARM SYSTEM.

Classification of Work: Alterations Level 2 per IEBC Section 404
Reconfiguration of Space.

Alterations Level 2 shall comply with IEBC 2009 Chapter 6 and 7
(Section numbers noted below are from IEBC unless noted otherwise)

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/12/14

IEBC Chapter 6 – Alterations Level 1

602 - Building Elements and Materials (All sections comply, see Architectural plans)
602.1 Interior Finishes – New wall and ceiling finishes shall comply with IBC Chapter 8 and NFPA Life Safety 101 Code Section 10.2
602.2 Interior Floor Finish – New interior floor finishes and carpet shall comply with IBC Section 804.
602.3 Interior trim – New trim materials shall comply with IBC Section 806.

603 – Fire Protection
603.1 Alterations shall be done in a manner that maintains the level of fire protection provided. (See Section 704 below)

606 – Structural
Installation of new rooftop equipment (if applicable) shall comply with gravity load requirements of the IBC.

607 – Energy Efficiency
Alterations and new construction components shall comply with the requirements of the IECC without requiring the entire existing building to comply.

IEBC Chapter 7 Alterations Level 2

702 – Special Use and Occupancy
Not applicable

703 – Building Elements and Materials
703.2.2 Supplemental shaft and floor opening enclosure and 703.2.3 Supplemental stairway enclosure requirements – Not applicable (work area less than 50% of floor area)
703.3 Smoke barriers – Not applicable (Not group I-2)
703.4 Interior finish – Wall and ceiling finishes at exits and corridors shall comply with IBC and NFPA Life Safety 101.
703.5 Guards – No conditions requiring Guards exists.

704 – Fire Protection
Complies.

704.4 Fire Alarm and Detection. Complies. Upgraded in 2013.

705 – Means of Egress
Not applicable – Scope of this section is limited to work areas that include exits or corridors that are shared by more than one tenant.

706 – Accessibility
Complies

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/12/14

707 – Structural
No additions or modifications to existing structural systems or compone

708 – Electrical
New Work to comply with Section 708.1.

709 – Mechanical
(See Architectural plans for requirements for reconfigured spaces)

710 – Plumbing
Not applicable.

711 – Energy Efficiency
Alterations and new construction components shall comply with the requirements of the IECC without requiring the entire existing to comply.

EGRESS REQUIREMENTS (PER IBC CHAPTER 10)

CEILING HEIGHT FOR MEANS OF EGRESS SHALL BE 7'-6" (PER IBC 1003.2)

OCCUPANT LOAD (PER IBC 1004.1.1)

MERCANTILE - 1 OCCUPANT PER 30 GROSS SF.
10,266 SF / 30 = 343 PERSONS

BUSINESS AREAS – 1 OCCUPANT PER 100 GROSS SF.
701 SF / 100 = 7 PERSONS

STORAGE AREAS - 1 OCCUPANT PER 300 GROSS SF.
1,068 SF / 300 = 4 PERSONS

TOTAL OCCUPANTS – 354 PERSONS.

EGRESS WIDTH (PER IBC 1005.1)
EXISTING STAIRWAYS. NOT APPLICABLE.

EGRESS ILLUMINATION (PER IBC 1006)
MEANS OF EGRESS ILLUMINATION SHALL BE PROVIDED IN ACCORDANCE WITH SECTION 1006)

ACCESSIBLE MEANS OF EGRESS (PER IBC 1007)
NOT REQUIRED PER 1007.1, EXCEPTION #1 FOR ALTERATIONS TO EXISTING BUILDINGS. COMPLIES.

DOORS (PER IBC 1008)

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/12/14

EXISTING EXIT DOORS TO REMAIN AT FIRST FLOOR, (COMPLIES
ARCHITECTURAL PLANS)

STAIRWAYS (PER IBC 1009)
NOT APPLICABLE.

RAMPS (PER IBC 1010) NOT APPLICABLE (PROJECT CONTAINS NO RAMPS)

EXIT SIGNS (PER IBC 1011)
EXIT SIGNS SHALL BE PROVIDED PER SECTION 1011 (SEE LS-1 LIFE SAFETY PLAN)

HANDRAILS (PER IBC 1012)
NOT APPLICABLE.

GUARDS (PER IBC 1013)
NOT APPLICABLE.

EXIT ACCESS (PER IBC 1014)
PROPOSED LAYOUT COMPLIES WITH ALL REQUIREMENTS INCLUDING COMMON PATH OF TRAVEL WHICH SHALL BE 75' MAX. PER IBC 1014.3 and 100” MAX per NFPA Life Safety 101 Code Section 37.2.5.3.1

EXIT AND EXIT ACCESS DOORWAYS (PER IBC 1015) COMPLIES

EXIT ACCESS TRAVEL DISTANCE (PER IBC 1016) 250’ MAX. (WITH SPRINKLER) and NFPA Life Safety Code 101, COMPLIES

AISLES (PER IBC 1017) 36" MIN., COMPLIES

CORRIDORS (PER IBC 1018)
NO RATING REQUIRED PER TABLE 1018.1 FOR USE 'M' WITH SPRINKLER SYSTEM. WIDTH SHALL BE 44" MIN. PER 1018.2, COMPLIES

DEAD ENDS SHALL NOT EXCEED 50' PER 1018.4, EXCEPTION #2, COMPLIES WITH SPRINKLER SYSTEM.

EGRESS BALCONIES (PER IBC 1019) NOT APPLICABLE

EXITS (PER IBC 1020) COMPLIES
NUMBER OF EXITS PER IBC 1021.1.

Life Safety Code Specific Review:

37.1 – Mercantile.

37.1.4.2.1 – Subclassification of Occupancy – Class “B”.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/12/14

37.1.6 – Min. Construction Requirements. None. See IBC Code Requir
Above (2B, non-combustible).

37.2 – Means of Egress Requirements. Refers to Chapter 7 of NFPA Life Safety 101.

Chapter 7 Means of Egress

7.1.3.1 – Exit Access Corridors. N/A
7.1.3.2 Exits

7.1.5 Headroom. Conforms. > 7'-6" min.

7.2.2 Stairs. N/A.

7.2.2.6.3.1 Outside Stairs. Conforms.

7.2.5 Ramps. N/A.

7.3.1.2 Occupant Load Factor (No Changes). See IBC Chapter 10 Information Above.

7.3.2 Measurement of Means of Egress.

7.3.4 Min. Width. 36" for New Construction. Conforms.

7.3.4.1.2 Min. Width 28" for Existing Buildings. Conforms.

7.4 Number of Means of Egress. 2 Min., 3 Provided (Existing).

7.5 Arrangement of Means of Egress.

7.5.4.2 Conforms for Exit Remoteness.

7.9 Emergency Lighting. Complies.

7.10 Complies for Exit Signage.

Business Use Specific Sections:

37.2.2 Means of Egress. Complies.

37.2.2.3 Stairs. N/A.

37.2.4 Number of Exits, Complies. 3 Provided.

37.2.5.1 Means of Egress Arrangement. Existing Complies.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/12/14

37.2.5.2 Dead End Corridors 50' Max. Complies.

37.2.5.3.1 Common Path of Travel (Sprinklered). 100' Max. Complies.

37.2.5.4 Aisles. Complies.

37.2.5.7 One-Half of Egress Capacity at Street Entrance. Complies (72" egress width provided).

37.2.5.8 Egress Through Checkouts. None.

37.2.5.10 Wheeled Carts. Complies.

37.2.6 Travel Distance (Sprinklered) 250' Max. Complies.

37.2.8 Illumination of Means of Egress. Complies

37.2.9 Emergency Lighting. Complies. Exit Sign at Rear Sales Area Egress Door is wall mounted and will be suspended from Ceiling for better visibility. Noted on Plan A-2.1 and LS-1.

37.3.3.2.1 Interior Wall Finishes – to comply with Section 10.2.

37.3.4 Detection, Alarm & Communication Systems. Has Existing Monitored Fire Alarm System. Upgraded in 2013.