BRUCE
RONAYNE
HAMILTON
ARCHITECTS

RESURGAM CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/12/14

Fire Department Summary Sheet
Alterations to:
Rite Aid Store #4133
701 Forest Avenue
Portland, Maine

Date: January 8, 2014, by Randy Kangas, Associate
Project # 13-131

Applicant Information:

Bruce Ronayne Hamilton, AIA
Bruce Ronayne Hamilton Architects
833 Turnpike Road, PO Box 104
New Ipswich, NH 03071

(603) 878-4823

Project Architect:
Bruce Ronayne Hamilton, AIA

Project Manager:
Randy Kangas, Associate

Proposed Use of Structure:

Existing & Proposed Use: Mercantile (Per 2009, IBC and 2009 NFPA Life Safety 101 Code)

Square Footage of Existing Structure:

12,035 SF Existing Structure (no increase to building shell SF), One-Story. No new wall fenestration or Structural changes/additions.

Fire Protection:

Existing Automatic Fire Suppression System (to remain)

Separate Plans:

a) Suppression System Plans not required. Existing System to remain “as is”.
b) Detection System: Existing Fire Alarm System. See accompanying Code Review Notes.
c) Life Safety Plan: Sheet LS-1 included in Plan Set with 2009 NFPA Life Safety Code Information.