Inspections Division
Date: 04/16/14

ENERGY SERVICE CO.
"Optimizing Your Building's Performance"
4 Commercial Road • P.O. Box 908 • Scarborough, ME 04070-0908 • (207) 883-1473 FAX (207) 883-8371

Date: 4/10/14

Tammy Munson
Division Director
Planning & Urban Development Department
389 Congress St, Room 308
Portland, Maine 04101

Re.: **HVAC Unit Replacement**

Tammy,

I have been asked to review the HVAC unit replacements at the Rite Aid Pharmacy located at 701 Forest Ave, Portland Maine.

AAA Energy Service is planning to replace existing packaged rooftop units with new units of the same capacity. The new units weigh essentially the same as the existing units and I do not foresee any structural issues.

Please let me know if you have any questions or comments.

Respectfully Submitted,

D. Kelley

David Kelley, PE, LEED AP

AAA Energy Service Co.
"Optimizing Your Building's Performance"
Scarborough, ME | Pittsfield, ME | Auburn, NH

Office: 207.883.1473
Mobile: 207.318.3077
Email: dkelley@aaaenergy.com
Web: www.aaaenergy.com