EXISTING STAIRS
WITH NEW RAILINGS

PORCH SECTION (TYP) NO SCALE

After the fact permit requires post attachment detail, support of the beam on posts, lateral attachment to the main house structure in 2 locations per compliance with IRC Sec. R502.2.2

CITY OF PORTLAND, MAINE RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/09/13