Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/09/13

12 Irving Rebuild Existing Decks

These post blocks are not code compliant for frost protection and will need to be replaced with 4' sona tubes or piers