

10/10/01 - performed plumbing inspection on new bathroom - existing piping just shower installed in bathroom. OK. Tom M.

01/10/02 Inspected bedroom in basement apt.
Needs egress window or ^{another} separate sill height
exit before cert. of occ. can be issued. (69" opening 21 x 24)
Smoke Det's or Electrical will be insp. by M. Collins.

(Plumbing final I signed off) M. Collins

1-19-02 Contacted owner. by phone she is going to decide and amend permit to reflect change in plans, now

1-25-02 w/ Mike Noyes + M. Collins Met with MR + MRS STIMPSON they are going to install an egress window in basement bedroom before cert of Occ. is issued now

202 Dtl final insp. OK for
Cert of Occupancy
M. Collins



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 28 Vannah Ave

CBL 129 F011001

Issued to Stimson Mark A /n/a

Date of Issue 03/05/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 01-1145, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Nail Salon first floor & basement apartment
BOCA 1999 R-4 Type 5B

Limiting Conditions:

none

This certificate supersedes
certificate issued

Approved:

3/5/02 *Mark A Stimson*
(Date) Inspector

[Signature]
Inspector of Buildings

03/12/02
[Signature]

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.