

Memorandum

To: Project File/28 Vannah Ave/129 F011
From: Mike Nugent/ Manager of Inspection Services
Date: 02/01/2002
Re: Egress Window/28 Vannah Ave. Basement Apartment

Attached is the platform, egress window and handrails plan for the interior emergency escape, Pursuant to Section 121.1 of the Building Code, the head room can be reduced to accommodate the emergency escape and the stair and landing width can be reduced to 30 inches. All other elements must comply with all applicable sections of the code.

