

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
LEW/AUB IND PARK
AUBURN, MAINE 04210
207-784-1508

Job Name : 23 OCEAN AVE
Drawing : FIRST FLOOR
Location : PORTLAND, ME
Remote Area : FIRST FLOOR
Contract : 1-5744-SP-17
Data File : 5744 1ST.WXF

HYDRAULIC CALCULATIONS
for

Project name: 23 OCEAN AVE
Location: PORTLAND, ME
Drawing no: FIRST FLOOR
Date: 1/25/2018

Design

Remote area number: FIRST FLOOR
Remote area location: FIRST FLOOR
Occupancy classification: LIGHT HAZARD
Density: .10 - Gpm/SqFt
Area of application: 908 - SqFt
Coverage per sprinkler: 196 - SqFt
Type of sprinklers calculated: RELIABLE 5.6K F1FR56 1/2" 200 DEGREE
No. of sprinklers calculated: 10
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 307.432 - GPM @ 72.302 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 6/22/2016
Location: PLEASANT & FORREST
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: 170 KITTYHAWK AVE AUBURN, ME 04210
Phone number: 207-784-1507
Name of designer: S. COTE
Authority having jurisdiction: PORTLAND FIRE DEPARTMENT
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C

EASTERN FIRE PROTECTION
23 OCEAN AVE


Page 2
Date 1/25/2018

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 80
C2 - Residual Flow : 1209

Demand:

D1 - Elevation : 5.414
D2 - System Flow : 207.432
D2 - System Pressure : 72.302
Hose (Demand) : 100
D3 - System Demand : 307.432
Safety Margin : 9.539



Fittings Used Summary

EASTERN FIRE PROTECTION
23 OCEAN AVE

Page 3
Date 1/25/2018

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	82.0	80	1209.0	81.841	307.43	72.302

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
FP1	0.0	5.6	12.25	19.6	
F1	110.5	5.45	13.32	19.88	K=K @ FP2
F2	110.5	5.45	12.94	19.6	K=K @ FP2
F3	110.5	5.45	13.79	20.23	K=K @ FP2
F4	110.5	5.45	13.11	19.73	K=K @ FP2
F5	110.5	5.45	13.6	20.09	K=K @ FP2
F6	110.5	5.45	14.57	20.8	K=K @ FP2
F7	110.5	5.45	14.39	20.67	K=K @ FP2
F8	110.5	5.45	14.72	20.9	K=K @ FP2
F9	110.5	5.45	16.93	22.41	K=K @ FP2
F10	110.5	5.45	18.02	23.12	K=K @ FP2
100	109.166		15.32		
101	109.166		15.33		
102	109.166		15.45		
103	109.166		15.63		
104	109.166		16.07		
105	109.166		16.3		
106	109.166		17.25		
107	109.166		17.68		
108	109.166		19.33		
109	109.166		20.74		
110	109.166		39.0		
111	109.166		40.65		
10	99.5		47.99		
11	98.666		60.89		
TOW	98.666		63.42		
HDW	92.666		69.58		
BASE	91.666		74.35		
TEST	98.0		72.3	100.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
23 OCEAN AVE

Page 5
Date 1/25/2018

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
FP1 to FP2	0 0	5.60	19.60 19.6	1 1.101	T	9.563 0.0	1.000 9.562 10.562	150 0.0655	12.250 0.0 0.692		Vel = 6.60	
FP2			0.0 19.60						12.942		K Factor = 5.45	
F1 to 100	110.500 109.166	5.45	19.88 19.88	1 1.049	E T	3.022 7.555 0.0	6.166 10.577 16.743	150 0.0852	13.317 0.578 1.426		K = K @ FP2 Vel = 7.38	
100			0.0 19.88						15.321		K Factor = 5.08	
F2 to 101	110.500 109.166	5.45	19.60 19.6	1 1.049	2E T	6.044 7.555 0.0	8.250 13.599 21.849	150 0.0830	12.942 0.578 1.813		K = K @ FP2 Vel = 7.28	
101			0.0 19.60						15.333		K Factor = 5.01	
F3 to 102	110.500 109.166	5.45	20.23 20.23	1 1.049	E T	3.022 7.555 0.0	1.833 10.577 12.410	150 0.0879	13.785 0.578 1.091		K = K @ FP2 Vel = 7.51	
102			0.0 20.23						15.454		K Factor = 5.15	
F4 to 103	110.500 109.166	5.45	19.73 19.73	1 1.049	E T	3.022 7.555 0.0	12.500 10.577 23.077	150 0.0839	13.113 0.578 1.937		K = K @ FP2 Vel = 7.32	
103			0.0 19.73						15.628		K Factor = 4.99	
F5 to 104	110.500 109.166	5.45	20.09 20.09	1 1.049	2E T	6.044 7.555 0.0	8.250 13.599 21.849	150 0.0868	13.597 0.578 1.897		K = K @ FP2 Vel = 7.46	
104			0.0 20.09						16.072		K Factor = 5.01	
F6 to 105	110.500 109.166	5.45	20.80 20.8	1 1.049	E T	3.022 7.555 0.0	1.833 10.577 12.410	150 0.0925	14.570 0.578 1.148		K = K @ FP2 Vel = 7.72	
105			0.0 20.80						16.296		K Factor = 5.15	
F7 to 106	110.500 109.166	5.45	20.67 20.67	1 1.049	E T	3.022 7.555 0.0	14.375 10.577 24.952	150 0.0915	14.390 0.578 2.284		K = K @ FP2 Vel = 7.67	
106			0.0 20.67						17.252		K Factor = 4.98	
F8 to 107	110.500 109.166	5.45	20.90 20.9	1 1.049	2E T	6.044 7.555 0.0	11.916 13.599 25.515	150 0.0934	14.717 0.578 2.384		K = K @ FP2 Vel = 7.76	
107			0.0 20.90						17.679		K Factor = 4.97	
F9 to 108	110.500 109.166	5.45	22.41 22.41	1 1.049	E T	3.022 7.555 0.0	6.625 10.577 17.202	150 0.1063	16.926 0.578 1.829		K = K @ FP2 Vel = 8.32	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
23 OCEAN AVE

Page 6
Date 1/25/2018

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0 22.41						19.333		K Factor = 5.10	
F10 to 109	110.500 109.166	5.45	23.12	1	2E T	6.044 7.555 0.0	5.416 13.599 19.015	150	18.016 0.578 2.141		K = K @ FP2	
			23.12	1.049				0.1126			Vel = 8.58	
			0.0 23.12						20.735		K Factor = 5.08	
100 to 101	109.166 109.166		19.88	1.5		0.0 0.0 0.0	1.333 0.0 1.333	150	15.321 0.0 0.012		Vel = 2.87	
101 to 102	109.166 109.166		19.60	1.5		0.0 0.0 0.0	4.000 0.0 4.000	150	15.333 0.0 0.121		Vel = 5.70	
102 to 103	109.166 109.166		20.23	1.5		0.0 0.0 0.0	2.666 0.0 2.666	150	15.454 0.0 0.174		Vel = 8.62	
103 to 104	109.166 109.166		19.73	1.5		0.0 0.0 0.0	4.000 0.0 4.000	150	15.628 0.0 0.444		Vel = 11.47	
104 to 105	109.166 109.166		20.09	1.5		0.0 0.0 0.0	1.333 0.0 1.333	150	16.072 0.0 0.224		Vel = 14.37	
105 to 106	109.166 109.166		20.79	1.5		0.0 0.0 0.0	4.000 0.0 4.000	150	16.296 0.0 0.956		Vel = 17.37	
106 to 107	109.166 109.166		20.67	1.5		0.0 0.0 0.0	1.333 0.0 1.333	150	17.252 0.0 0.427		Vel = 20.36	
107 to 108	109.166 109.166		20.90	1.5		0.0 0.0 0.0	4.000 0.0 4.000	150	17.679 0.0 1.654		Vel = 23.38	
108 to 109	109.166 109.166		22.42	1.5		0.0 0.0 0.0	2.666 0.0 2.666	150	19.333 0.0 1.402		Vel = 26.61	
109 to 110	109.166 109.166		23.12	1.5	J	14.959 0.0 0.0	12.958 14.960 27.918	150	20.735 0.0 18.269		Vel = 29.95	
			0.0 207.43						39.004		K Factor = 33.21	
110 to 111	109.166 109.166		207.43	2	V	6.509 0.0 0.0	1.958 6.509 8.467	150	39.004 0.0 1.650		Vel = 18.21	
111 to 10	109.166 99.500		0.0	2	V	6.509 0.0 0.0	9.666 6.509 16.175	150	40.654 4.186 3.152		Vel = 18.21	
			0.0 207.43						47.992		K Factor = 29.94	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
23 OCEAN AVE

Page 7
Date 1/25/2018

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10 to 11	99.500 98.666		207.43	2	2V 2T	8.615 24.613	9.333 33.228	120	47.992 0.361			
			207.43	2.157		0.0	42.561	0.2945	12.533	Vel = 18.21		
11 to TOW	98.666 98.666		0.0	2.5	V	5.903 0.0	16.916 5.903	120	60.886 0.0			
			207.43	2.635		0.0	22.819	0.1110	2.534	Vel = 12.20		
TOW to HDW	98.666 92.666		0.0	2.5	B T	9.61 16.474	6.000 26.084	120	63.420 2.599			
			207.43	2.635		0.0	32.084	0.1111	3.564	Vel = 12.20		
HDW to BASE	92.666 91.666		0.0	4	2E	26.334 0.0	5.000 26.334	120	69.583 4.433		** Fixed Loss = 4	
			207.43	4.26		0.0	31.334	0.0107	0.336	Vel = 4.67		
BASE to TEST	91.666 98		0.0	4	E T G	14.534 29.067 2.907	25.000 46.508 71.508	140	74.352 -2.743 0.693			Vel = 5.04
			100.00							Qa = 100.00		
TEST			307.43						72.302	K Factor = 36.16		