

Helen Donaldson <hcd@portlandmaine.gov>

23 Ocean Avenue plat

William Clark <wbc@portlandmaine.gov>
To: Helen Donaldson <hcd@portlandmaine.gov>

Fri, Sep 23, 2016 at 11:27 AM

Hi Nell,

I wish all the plans took care of the details as well as this one. Mr Dostie (Surveyor) does real professional work.

I would just ask for three minor items. Survey review plan markup attached.

- 1. Add chord bearing and distance for the proposed pedestrian easement detail.
- 2. Add text "Proposed" before "Pedestrian Easement".
- 3. Possibly add height clearance for the one foot wide aerial easements along Ocean Ave and Hersey St.

Thanks,

Bill

[Quoted text hidden]

-

William Clark, PLS Senior Project Engineer DPW Engineering City of Portland 55 Portland St. Portland, ME 04101 207 874 8847

_

Ocean Ave No 23 Site Subdivision Plat 9 14 2016 Survey Review 9 23 2016.PDF 818K

