

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

UNITED USA LLC

Located at

671 FOREST AVE

PERMIT ID: 2014-02078

ISSUE DATE: 10/28/2014

CBL: 129 L002001

has permission to **Phase 2 - Renovate existing second floor storage into 5 apartments. No planned changes to first floor.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

1st floor - two retail spaces, 2nd floor storage, basement storage
#2014-02078 changes the use to 1st floor retail spaces with 5 residential units on 2nd floor

Building Inspections

Use Group: R-2 Type: 5B
Residential Dwelling Units (5)
Occupant Load = 13
NFPA 13R
Second Floor Only
MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Certificate of Occupancy/Final

Final - Electric

Fire - Change of Use Inspection

Final - DRC

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02078	Date Applied For: 09/09/2014	CBL: 129 L002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Retail 1st floor & five (5) Residential on 2nd floor		Proposed Project Description: Phase 2 - Renovate existing second floor storage into 5 apartments. No planned changes to first floor.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 09/10/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This property shall remain retail units on the first floor with five (5) residential dwelling units on the second floor with the issuance of this permit. Any change of use shall require a separate permit application for review and approval.		
Dept: Building		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 10/27/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. SEE ADDITIONAL SPECIFICATIONS FOR THE FIRE SEPARATION WALL CONSTRUCTION PER UL U305.		
		2) Draftstopping and Fireblocking in combustible concealed spaces and locations shall be in accordance with IBC Sec. 717 or IRC Sec. R302.11 & 302.12		
		3) The continuity of the fire resistance rated wall or floor/ceiling assembly shall be installed and maintained as described in IBC Ch. 7 and all penetrations shall be treated with approved materials and methods.		
		4) Penetrations through fire resistance rated assemblies shall be protected by an approved penetration firestop system installed as tested in accordance with ASTM E814 or UL 1479		
		5) Any modifications to existing building systems and all new systems (HVAC, electrical and service water heating) shall meet IECC 2009 or ASHRAE 90.1-2007 requirements for energy code compliance.		
		6) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.		
Dept: Fire		Status: Approved w/Conditions	Reviewer: David Petrucci	Approval Date: 10/03/2014
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) The installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine		
		2) Shall comply with 2009 NFPA 1 Chapter 16 Safeguards During Building Construction, Alteration, and Demolition Operations. Any cutting and welding done will require a Hot Work Permit from Fire Department.		
		3) Single-station Carbon Monoxide (CO) alarms powered by the building's electrical service with battery backup are required within the dwelling units. CO alarms shall be installed in the following locations: (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces New CO alarms shall be hardwired.		
		4) All smoke detectors shall be photoelectric.		

