

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

CADORETTE RICK V & MEGAN V MCLAUGHLIN-
CADORETTE

Located at

205 WOODFORD ST

PERMIT ID: 2015-02502

ISSUE DATE: 11/12/2015

CBL: 130 F020001

has permission to **Change of Use only to a Court Reporting Agency ("Gaige & Felicitti LLC" -
Court Reporters/Video Conferencing) - No structural changes.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Single-family residence with office (court reporting agency)

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final
Fire - Change of Use Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02502	Date Applied For: 10/14/2015	CBL: 130 F020001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single-family residence with court reporting agency ("Gauge & Felicitti LLC" - Court Reporters/Video Conferencing)		Proposed Project Description: Change of Use only to a Court Reporting Agency ("Gauge & Felicitti LLC" - Court Reporters/Video Conferencing) - No structural changes.		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 10/19/2015</p> <p>Note: B-1 zone Ok to Issue: <input checked="" type="checkbox"/></p> <p>Convert use of garage from day care/school to office - allowed use in B-1</p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving a change of use only 2) This property shall remain a single family dwelling with office. Any change of use shall require a separate permit application for review and approval. 3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 5) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals. 				
<p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 11/12/2015</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) This is a Change of Use ONLY permit. It does NOT authorize any construction activities. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 				
<p>Dept: Fire Status: Approved w/Conditions Reviewer: David Petruccelli Approval Date: 11/03/2015</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <ol style="list-style-type: none"> 1) Shall meet the requirements of 2009 NFPA 1 Fire Code. 2) Fire extinguishers are required per NFPA 1 Table 13.6.2. 3) All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf 4) Shall meet the requirements of 2009 NFPA 101 Life Safety Code Chapter 38 New Business. 				