

City of Portland, Maine
Inspections Division
Violations Report

Appointment Date Between 3/1/2018 And 4/5/2018

Dist. #	Sch. Date	CBL	Appl. Type	Schedule Type	Appl #	Location
	Contact:		Inspector	Comments		
4	03/16/2018	130 G007001	Fire Company	FP Routine Inspection		710 FOREST AVE
HSL Yr	DELTA REALTY LLC		Paul Marshall			

Code	Violation	Status	IntExt	Floor	Area	Corrected	Date
NFPA 101-7.9.3-80.16	Emergency lights Require Maintenance Emergency light in office not working	Open				<input type="checkbox"/>	
NFPA 10-7.2.4.4-81.20	Fire Extinguisher Inspection Tag Extinguisher near overhead door missing inspection tag	Open				<input type="checkbox"/>	
NFPA 1-89.05	Excessive/disorderly Storage Storage around heating units in utility room.	Open				<input type="checkbox"/>	

Total Listed: 1