
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager BATES FREDERICK A TRUSTEE		Inspector Jon Rioux	Inspection Date 3/9/2007
Location 732 FOREST AVE	CBL 130 H017001	Status Re-Inspect 30 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.2	Interior		ALL		
Violation:	Interior floors, walls, ceilings and doors				
Notes:	Repair the second egress stairwell ceiling, and patch the main stairwell walls so that they are in structurally sound condition and vermin proof.				

Comments: