



**... Fire Protection by Computer Design**

DEAN AND ALLYN, INC.  
116 LEWISTON ROAD  
GRAY MAINE  
207 657 5646

Job Name : 732 FOREST AVE BASEMENT  
Building :  
Location : 732 FOREST AVE PORTLAND MAINE  
System : ONE  
Contract : C171466  
Data File : 732 FOREST AVE BASEMENT.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 732 FOREST AVE BASEMENT Date - 10-10-17  
Location - 732 FOREST AVE PORTLAND MAINE  
Building - System No. - ONE  
Contractor - DEAN AND ALLYN, INC. Contract No. - C171466  
Calculated By - H. KING Drawing No. - 1 OF 1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 8'  
OCCUPANCY - APARTMENTS

S Type of Calculation: ( )NFPA 13 Residential ( )NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 ( )4 ( )  
S ( )Other ORDINARY HAZARD I IN BASEMENT  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 14.8 Gpm System Type  
Listed Pres. at Start Point - 7 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 10 x 10 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make RELIABLE Model F1FR56  
I Elevation at Highest Outlet - 0 Feet Size 1/2" K-Factor 5.6  
G Note:CUSHION 5.8 PSI Temperature Rating 155  
N

Calculation Gpm Required 461 Psi Required 75.8 AT CITY  
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 6-22-17 Rated Cap. Cap.  
T Time of Test - @ Psi Elev.  
E Static (Psi) - 82 Elev.  
R Residual (Psi) - 80 Other Well  
Flow (Gpm) - 1209 Proof Flow Gpm  
S Elevation - 0

P Location: IN FRONT OF BUILDING ON 16" CITY MAIN

P Source of Information: PORTLAND WATER DEPT.  
L  
Y

# Final Calculations - Hazen-Williams

DEAN AND ALLYN, INC.  
732 FOREST AVE BASEMENT

Page 2  
Date 10-10-17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 2	15.00 15.0	1.049 120.0 0.0764		0.0 0.0 0.0	9.000 0.0 9.000	7.175 0.0 0.688			K Factor = 5.60 Vel = 5.57	
2 to 20	15.70 30.7	1.38 120.0 0.0756	E T	3.0 6.0 0.0	10.300 9.000 19.300	7.863 0.0 1.459			K Factor = 5.60 Vel = 6.59	
	0.0 30.70					9.322			K Factor = 10.06	
3 to 4	15.13 15.13	1.049 120.0 0.0777		0.0 0.0 0.0	9.000 0.0 9.000	7.295 0.0 0.699			K Factor = 5.60 Vel = 5.62	
4 to 20	15.83 30.96	1.38 120.0 0.0768	E T	3.0 6.0 0.0	8.300 9.000 17.300	7.994 0.0 1.328			K Factor = 5.60 Vel = 6.64	
	0.0 30.96					9.322			K Factor = 10.14	
5 to 6	79.34 79.34	1.61 120.0 0.2068		0.0 0.0 0.0	10.000 0.0 10.000	9.971 0.0 2.068			K Factor = 5.60 Vel = 12.50	
6 to 21	19.43 98.77	2.067 120.0 0.0918	2T	20.0 0.0 0.0	9.000 20.000 29.000	12.039 0.0 2.663			K Factor = 5.60 Vel = 9.44	
	0.0 98.77					14.702			K Factor = 25.76	
7 to 22	16.76 16.76	1.049 120.0 0.0939	E T	2.0 5.0 0.0	5.500 7.000 12.500	8.962 0.0 1.174			K Factor = 5.60 Vel = 6.22	
	0.0 16.76					10.136			K Factor = 5.26	
8 to 22	16.76 16.76	1.049 120.0 0.0939	E T	2.0 5.0 0.0	5.500 7.000 12.500	8.962 0.0 1.174			K Factor = 5.60 Vel = 6.22	
	0.0 16.76					10.136			K Factor = 5.26	
9 to 10	51.63 51.63	1.61 120.0 0.0934		0.0 0.0 0.0	10.000 0.0 10.000	10.447 0.0 0.934			K Factor = 5.60 Vel = 8.14	
10 to 23	18.89 70.52	1.61 120.0 0.1663	2T	16.0 0.0 0.0	9.000 16.000 25.000	11.381 0.0 4.157			K Factor = 5.60 Vel = 11.11	
	0.0 70.52					15.538			K Factor = 17.89	
11 to 12	20.40 20.4	1.049 120.0 0.1350		0.0 0.0 0.0	9.000 0.0 9.000	13.268 0.0 1.215			K Factor = 5.60 Vel = 7.57	
12 to 24	21.31 41.71	1.38 120.0 0.1333	E T	3.0 6.0 0.0	9.000 9.000 18.000	14.483 0.0 2.400			K Factor = 5.60 Vel = 8.95	

# Final Calculations - Hazen-Williams

DEAN AND ALLYN, INC.  
732 FOREST AVE BASEMENT

Page 3  
Date 10-10-17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 41.71						16.883		K Factor = 10.15	
20 to 5	61.66 61.66	1.61 120.0 0.1298		0.0 0.0 0.0	5.000 0.0 5.000	9.322 0.0 0.649			Vel = 9.72	
	0.0 61.66						9.971		K Factor = 19.53	
21 to 23	98.77 98.77	2.067 120.0 0.0919		0.0 0.0 0.0	9.100 0.0 9.100	14.702 0.0 0.836			Vel = 9.44	
	0.0 98.77						15.538		K Factor = 25.06	
22 to 9	33.53 33.53	1.38 120.0 0.0889		0.0 0.0 0.0	3.500 0.0 3.500	10.136 0.0 0.311			Vel = 7.19	
	0.0 33.53						10.447		K Factor = 10.37	
23 to 26	169.30 169.3	2.067 120.0 0.2488	T	10.0 0.0 0.0	8.000 10.000 18.000	15.538 0.0 4.479			Vel = 16.19	
	0.0 169.30						20.017		K Factor = 37.84	
24 to 13	41.71 41.71	1.61 120.0 0.0630		0.0 0.0 0.0	5.000 0.0 5.000	16.883 0.0 0.315			Vel = 6.57	
13 to 14	0.0 41.71	1.61 120.0 0.0629		0.0 0.0 0.0	10.000 0.0 10.000	17.198 0.0 0.629			Vel = 6.57	
14 to 25	0.0 41.71	1.61 120.0 0.0629	2T	16.0 0.0 0.0	9.000 16.000 25.000	17.827 0.0 1.573			Vel = 6.57	
25 to 26	0.0 41.71	1.61 120.0 0.0630	T	8.0 0.0 0.0	1.800 8.000 9.800	19.400 0.0 0.617			Vel = 6.57	
26 to TR	169.29 211.0	2.067 120.0 0.3740	E	5.0 0.0 0.0	5.000 5.000 10.000	20.017 0.0 3.740			Vel = 20.17	
TR to FF	0.01 211.01	2.067 120.0 0.3740	S	11.0 0.0 0.0	7.000 11.000 18.000	23.757 5.000 6.732		** Fixed Loss = 5	Vel = 20.17	
FF to CTY	-0.01 211.0	1.72 120.0 0.9153	T	4.086 0.0 0.0	40.000 4.086 44.086	35.489 0.0 40.353			Vel = 29.14	
	250.00 461.00						75.842		Qa = 250.00 K Factor = 52.94	

# Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.  
732 FOREST AVE BASEMENT

Page 4  
Date 10-10-17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	0.0	5.6	7.17	na	15.0	0.15	100	7.0
2	0.0	5.6	7.86	na	15.7	0.15	100	7.0
3	0.0	5.6	7.3	na	15.13	0.15	100	7.0
4	0.0	5.6	7.99	na	15.83	0.15	100	7.0
5	0.0	5.6	9.97	na	17.68	0.15	100	7.0
6	0.0	5.6	12.04	na	19.43	0.15	100	7.0
7	0.0	5.6	8.96	na	16.76	0.15	100	7.0
8	0.0	5.6	8.96	na	16.76	0.15	100	7.0
9	0.0	5.6	10.45	na	18.1	0.15	100	7.0
10	0.0	5.6	11.38	na	18.89	0.15	100	7.0
11	0.0	5.6	13.27	na	20.4	0.15	100	7.0
12	0.0	5.6	14.48	na	21.31	0.15	100	7.0
20	0.0		9.32	na				
21	0.0		14.7	na				
22	0.0		10.14	na				
23	0.0		15.54	na				
24	0.0		16.88	na				
13	0.0		17.2	na				
14	0.0		17.83	na				
25	0.0		19.4	na				
26	0.0		20.02	na				
TR	0.0		23.76	na				
FF	0.0		35.49	na				
CTY	0.0		75.84	na	250.0			

The maximum velocity is 29.14 and it occurs in the pipe between nodes FF and CTY

# Water Supply Curve C

DEAN AND ALLYN, INC.  
732 FOREST AVE BASEMENT

Page 5  
Date 10-10-17

### City Water Supply:

C1 - Static Pressure : 82  
C2 - Residual Pressure: 80  
C2 - Residual Flow : 1209

### Demand:

D1 - Elevation : \_\_\_\_\_  
D2 - System Flow : 211.006  
D2 - System Pressure : 75.842  
Hose ( Demand ) : 250  
D3 - System Demand : 461.006  
Safety Margin : 5.822

