

# Sequence of Operations

	Audio/visual activation globally on general alarm	Audio/visual activation locally within the unit on local alarm only	Activate audible/visual signal at FACP & Annunciator	Device Description at FACP & Annunciator	Shutdown of HVAC equipment	Log event in system history	Activate Elevator Fire Hat	Activate Elevator primary or secondary control	Activate Elevator shunt trip	Silence of audible devices Including FACP & annunciator	Release door holders	Release locked doors	Event acknowledgement	Reset of all system functions and all visual devices	Remote transmission to Central Station A=alarm; T=trouble; S=Supervisory; L = log only	Remote indicator
Manual Pull Stations	X		X	X		X					X	X			A	
Smoke detectors common area	X		X	X		X					X	X			A	
Smoke detectors elevator lobbies	X		X	X		X		X			X	X			A	
Smoke Detectors elevator shaft/machine room	X		X	X		X	X	X			X	X			A	
Duct mounted Smoke Detectors			X	X	X	X									S	X
Smoke detectors with sounder base		X	X	X		X									S	
Sounder on smoke detector with sounder base	X															
Heat Detectors common area	X		X	X		X					X	X			A	
Heat Detectors Elevator shaft/machine room	X		X	X		X	X	X			X	X			A	
Sprinkler flow or pressure switches	X		X	X		X					X	X			A	
Sprinkler Tamper, low temp, or low air			X	X		X									S	
Secondary fire panel such as kitchen hood	X		X	X		X					X	X			A	
FACP/annunciator silence button			X	X		X				X					L	
FACP/annunciator acknowledge button			X	X		X							X			

# Sequence of Operations

	Audio/visual activation globally on general alarm	Audio/visual activation locally within the unit on local alarm only	Activate audible/visual signal at FACP & Annunciator	Device Description at FACP & Annunciator	Shutdown of HVAC equipment	Log event in system history	Activate Elevator Fire Hat	Activate Elevator primary or secondary control	Activate Elevator shunt trip	Silence of audible devices Including FACP & annunciator	Release door holders	Release locked doors	Event acknowledgement	Reset of all system functions and all visual devices	Remote transmission to Central Station A=alarm; T=trouble; S=Supervisory; L = log only	Remote indicator
FACP/annunciator reset button			X	X		X								X	L	
Removal of any device			X	X		X									T	
Ground fault			X	X		X									T	
System wiring "open"			X	X		X									T	
AC Power loss			X	X		X									T	
Secondary power loss			X	X		X									T	
Telephone line loss			X	X		X									T	