

Certificate of occupancy issued subject to the following conditions: (1) required Standard Class C fire door (labelled) to be provided at boiler room enclosure as soon as procurable; (2) effective and approved closing device to be provided for this fire door forthwith (see letter of January 14, 1944).