

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : PLEASANT AVENUE APARTMENTS
Building : WOOD STRUCTURE
Location : THIRD FLOOR
System : 1
Contract : C16015
Data File : PLEASANT AVE APT-3RD FLR.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - PLEASANT AVE APARTMENTS Date - 6-30-2016
Location - THIRD FLOOR
Building - WOOD STRUCTURE System No. - 1
Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16015
Calculated By - T. PRAY Drawing No. - 2 OF 2
Construction: (X) Combustible () Non-Combustible Ceiling Height 12'-4"
OCCUPANCY - APARTMENT

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 16 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 18' () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make VIKING Model VK486
I Elevation at Highest Outlet - 133.17Feet Size 7/16" K-Factor 4.0
G Note: Temperature Rating 155
N

Calculation Gpm Required 63.51 Psi Required 70.83 At Test
Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 6-30-2016 Rated Cap. Cap.
T Time of Test - 9:00 AM @ Psi Elev.
E Static (Psi) - 82 Elev.
R Residual (Psi) - 80 Other Well
Flow (Gpm) - 1209 Proof Flow Gpm
S Elevation - 99.0'

P Location: HYDRANTS ARE LOCATED ON PLEASANT AVE, SEE PLOT PLAN

L Source of Information: PORTLAND WATER DISTRICT
Y

Water Supply Curve (C)

Residential Fire Protection
PLEASANT AVENUE APARTMENTS


Page 2
Date 6/1/16

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 80
C2 - Residual Flow : 1209

Demand:

D1 - Elevation : 15.700
D2 - System Flow : 63.5095
D2 - System Pressure : 70.830
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 63.5095
Safety Margin : 11.162



Fittings Used Summary

Residential Fire Protection
PLEASANT AVENUE APARTMENTS

Page 3
Date 6/1/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
PLEASANT AVENUE APARTMENTS

Page 4
Date 6/1/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
BA01	0.0	5.6	10.33	na	18.0	0.15	120	7.0
40	133.17	4	10.6	na	13.02	0.0508	256	10.6
41	133.17	4	11.7	na	13.68	0.0508	256	10.6
42	133.17	4.9	15.73	na	19.43	0.0714	196	8.16
43	133.17	4	18.86	na	17.37	0.0508	256	10.6
100	133.17		20.99	na				
101	132.25		30.01	na				
102	132.25		33.11	na				
103	121.71		40.61	na				
104	108.25		49.24	na				
105	108.25		52.9	na				
106	97.75		60.63	na				
27	98.375		61.82	na				
28	98.42		62.24	na				
TOR	98.42		62.99	na				
BOR	92.92		72.54	na				
TEST	96.92		70.83	na				

The maximum velocity is 13.66 and it occurs in the pipe between nodes 43 and 100

Final Calculations - Hazen-Williams

Residential Fire Protection
PLEASANT AVENUE APARTMENTS

Page 5
Date 6/1/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BA01 to EQ01	18.00 18.0 0.0 18.00	1.049 120 0.1071	1T	5.0 0.0 0.0	0.790 5.000 5.790	10.332 0.0 0.620			K Factor = 5.60 Vel = 6.68	
							10.952		K Factor = 5.44	
40 to 41	13.02 13.02	1.049 120 0.0588	4E	8.0 0.0 0.0	10.710 8.000 18.710	10.600 0.0 1.101			K Factor = 4.00 Vel = 4.83	
41 to 100	13.69 26.71 0.0 26.71	1.049 120 0.2222	2E 1T	4.0 5.0 0.0	32.790 9.000 41.790	11.701 0.0 9.285			K Factor = 4.00 Vel = 9.92	
							20.986		K Factor = 5.83	
42 to 43	19.43 19.43	1.049 120 0.1234	4E	8.0 0.0 0.0	17.360 8.000 25.360	15.729 0.0 3.129			K Factor = 4.90 Vel = 7.21	
43 to 100	17.37 36.8	1.049 120 0.4023	1T	5.0 0.0 0.0	0.290 5.000 5.290	18.858 0.0 2.128			K Factor = 4.00 Vel = 13.66	
100 to 101	26.71 63.51	1.38 120 0.2902	2E 1T	6.0 6.0 0.0	17.710 12.000 29.710	20.986 0.398 8.622			Vel = 13.62	
101 to 102	0.0 63.51	1.38 120 0.2902	1T 1E	6.0 3.0 0.0	1.710 9.000 10.710	30.006 0.0 3.108			Vel = 13.62	
102 to 103	0.0 63.51	1.61 120 0.1370	2E	8.0 0.0 0.0	13.370 8.000 21.370	33.114 4.565 2.927			Vel = 10.01	
103 to 104	0.0 63.51	1.61 120 0.1370	1T	8.0 0.0 0.0	12.460 8.000 20.460	40.606 5.830 2.802			Vel = 10.01	
104 to 105	0.0 63.51	1.61 120 0.1370	2T	16.0 0.0 0.0	10.750 16.000 26.750	49.238 0.0 3.664			Vel = 10.01	
105 to 106	0.0 63.51	1.61 120 0.1370	1E 1T	4.0 8.0 0.0	11.250 12.000 23.250	52.902 4.548 3.185			Vel = 10.01	
106 to 27	0.0 63.51	1.61 120 0.1370	1T	8.0 0.0 0.0	2.625 8.000 10.625	60.635 -0.271 1.456			Vel = 10.01	
27 to 28	0.0 63.51	2.635 120 0.0124	1J	14.827 0.0 0.0	20.540 14.827 35.367	61.820 -0.019 0.439			Vel = 3.74	
28 to TOR	0.0 63.51	2.635 120 0.0124	2I	16.474 0.0 0.0	43.960 16.474 60.434	62.240 0.0 0.752			Vel = 3.74	
TOR to BOR	0.0 63.51	2.635 120 0.0124	1Z	8.237 0.0 0.0	5.500 8.237 13.737	62.992 9.382 0.170			* Fixed loss = 7 Vel = 3.74	

Final Calculations - Standard

Residential Fire Protection
 PLEASANT AVENUE APARTMENTS

Page 6
 Date 6/1/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BOR	0.0	6.16	2L 25.822	45.000	72.544				
to		140	1G 4.304	73.163	-1.732				
TEST	63.51	0.0002	1T 43.037	118.163	0.018		Vel = 0.68		
	0.0								
	63.51				70.830		K Factor = 7.55		