

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 14 August 1997

LOCATION: XXXXXXXX 42 Clinton St

Permit # 15110

OWNER Williams, Jeffrey ADDRESS _____

130-1-017

							TOTAL EACH FEE		
OUTLETS	Telephone		Data		CATV			.20	
	Receptacles		Switches		Smoke Detector			.20	
FIBER OPTICS								15.00	
FIXTURES	incandescent		fluorescent					.20	
	fluorescent strip							.20	
SERVICES	Overhead				TTL AMPS TO	800	200	15.00	
	Underground					800		15.00	
Temporary Service	Overhead				AMPS OVER	800		25.00	
	Underground					800		25.00	
METERS	(number of)						2	1.00	
MOTORS	(number of)							2.00	
RESID/COM	Electric units							1.00	
HEATING	oil/gas units		Interior		Exterior			5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens			2.00	
	Insta-Hot		Water heaters		Fans			2.00	
	Disposals		Dishwasher		Compactors			2.00	
MISC. (number of)	Air Cond/win				Others (denote)			3.00	
	Air Cond/cent				Pools			10.00	
	HVAC		EMS		Thermostat			5.00	
	Signs							10.00	
	Alarms/res							5.00	
	Alarms/com							15.00	
	Heavy Duty(CRKT)							2.00	
	Circus/Carnv							25.00	
	Alterations							5.00	
	Fire Repairs							15.00	
	E Lights							1.00	
	E Generators							20.00	
PANELS	Service		Remote		Main		2	4.00	
	TRANSFORMER	0-25 Kva						5.00	
	25-200 Kva							8.00	
	Over 200 Kva							10.00	
							TOTAL AMOUNT DUE		
MINIMUM FEE/COMMERCIAL 35.00							MINIMUM FEE	25.00	25.00

INSPECTION: Will be ready 8/19 PM or will call _____

CONTRACTORS NAME Folsom Electric MASTER LIC. # 15110
 ADDRESS 24 Sunset Rd Scarborough, ME LIMITED LIC. # _____
 TELEPHONE 883-8025

SIGNATURE OF CONTRACTOR *JB Folsom*

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service 8/19/07 by [Signature]
Service called in 8/19/07 by [Signature]
Closing-in _____ by _____

PROGRESS INSPECTIONS: 8/19/07 SERVICE

DATE:	REMARKS:
8/19/07	SE CRACK ON (AC SIDING) will not return again
	3' Clearance from window
	Electrician made aware of above