CITY OF PORTLAND FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

April 3, 2017

Responsible Party 1:	Responsible Party 2:		
BELANGER GLENN	Sarchi Tammy		
71 LAWN AVE	71 Lawn Ave		
PORTLAND, ME 04103	Portland, ME 04103		
Location	CBL	Inspection Date	
Location 71 LAWN AVE	CBL 131 F012001	Inspection Date 3/23/2017	
		_	

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 4/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
PORTLAND FIRE DEPARTMENT CHAPTER 10 4.6.1, 4.6.2 UNIT/SUITE NUMBERS NOT MARKED; 4.6.1 Residential units shall be designated using numerals. 4.6.2 The first numeral of each residential unit shall be the floor designation.	//
Label all apartment doors (Front and Rear)that enter into the common stairwells.	
NFPA 101- 7.2.1.15.8 FIRE DOOR ASSEMBLY REQ REPAIR; Door openings not in proper operating condition shall be repaired or replaced without delay. Fire doors with self-closing hardware must be installed for the basement door and the front and rear doors of the 3 apartment units.	//
NFPA 720- 5.5.6.1 CO ALARMS REQUIRED; The performance, location, and mounting of notification appliances used to initiate or direct action, evacuation or relocation of the occupants, or for providing information to occupants or staff, shall comply with the requirements of Chapter 6. Each apartment and the basement must have a Carbon Monoxide detector (hardwired) installed.	IMMEDIATELY install temporary alarms where required. Your signature below indicates that temporary alarms have already been installed.
CITY ORDINANCE HARDWIRED SMOKE DETECTORS REQUIRED; New smoke alarms shall be powered in accordance with NFPA 72. Where available options include: Hardwired with battery back up A non-rechargeable, non-replaceable primary battery that is capable of operating the device for at leat 10 years Existing smoke alarms shall be hardwired and replaced every 10 years with smoke alarms complying with the above notes. All new smoke alarms shall be photoelectric. In the basement, in apartment 2 near the kitchen and in the front 3rd floor bedroom.	•
NFPA 101- 31.3.2.1 HAZARDOUS AREAS SHALL BE PROTECTED; Any hazardous area shall be protected in accordance with Section 8.7. Install sprinkler coverage above the 1st floor furnace in the basement.	

Violation		Proposed Date of Completion
FINAL DATE OF COMPLET	ED VIOLATION(S)	//
FIRE PREVENTION BUREA	U RE-INSPECTION OF COMPLETED VIOLATION(S)	//
	ht to reject or modify any proposed plan of action, and manical capacity to complete the proposed plan. Please contaction	
understand that I must cont	tions listed within the timeframes provided. If I require actes the Fire Prevention Bureau prior to the deadline to resu's discretion to grant or deny.	1 1
v	is my responsibility to schedule a reinspection of my propo. My failure to schedule a reinspection shall be deemed medied.	
	agreement, I understand that I am liable for penalties purses $\S\S$ 1-15 and 10-25, and 30-A M.R.S. \S 4452 and may b	
Date	Responsible Party	
Date	Responsible Party	
SEEN AND AGREED		

Fire Prevention Bureau

Date